



Oregon

John A. Kitzhaber, M.D., Governor

Water Resources Department

Commerce Building
158 12th Street NE
Salem, OR 97310-0210
(503) 378-3739
FAX (503) 378-8130

December 24, 1998

Martin E. Warren
Merle Warren Well Drilling Inc.
34111 Highway 99 E
Tangent, OR 97389

Dear Shorty:

Please find enclosed copies of the following approved special standards:

1. Oremet - Wah Chang (start card numbers 87110, 87111, 99267, 116713, 116714 and 116715)

Please note that this approval also covers the work that you did at Oremet in the fall of 1997. If you have any questions concerning this letter, please contact me at the address or phone number listed above, or by e-mail at michael.l.mccord@wrdd.state.or.us.

Sincerely,

Michael L. McCord
Well Construction Specialist

c: Richard Edwards, Well Inspector

RECEIVED

STATE OF OREGON
WATER RESOURCES DEPARTMENT

DEC 18 1998

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON
WATER RESOURCES DEPT.
NOT SALEM, OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road, NE, Salem, OR 97310.

Date: 12-14-98

Well Constructor: Merle Warren Well Drilling, Inc.

(1) Location of Well: SW 1/4 NW 1/4 of Section 19,
Township 11S, Range 3W, Linn County.

Address at well site or nearest known address: 530 SW 34 St
Albany

(2) Name and address of Landowner: OreMet-Wah Chang
P.O. Box 460
Albany

(3) The distance to the nearest well and septic drainfield: _____

(4) The unusual conditions existing at the well site: installed
Cement-water bearing formation washed
Cement away

(5) The proposed construction methods that the well constructor or landowner constructing the well believes will be adequate for his particular well:
used cement grout - 25% sand
by weight - installed with 4" tennie
pipe

W-5M

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):

(Signed) 
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date: 12-23-98
Approved by: Michael J. McLeod
Denied by: _____
Remarks: SC #, 116715, 116714, 116713, 99267, 87111
and 87110

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.