

FINAL ORDER
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.


Date of request: 1-22-00 Oral approval date (if applicable): 1-22-00

Bonded Well Constructor (name, license #, and mailing address): Greg McInnis

- (1) Location of Well: NE 1/4 NE 1/4 of Section 29,
Township 18 N S Range 12 E W, Deschutes County.
Address at well site: China Hat Rd
- (2) Start Card Number(s): 125179
- (3) Name and Address of Land Owner: Avion Water Company
60813 Parrell Road Bend OR 97702
- (4) Distance to the nearest well, septic tank or drainfield (if water supply well): approx 200'
- (5) The unusual conditions which necessitate this request: Using sand gravel
back fill in place of bent or cement
- (6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)
Same as above

W-OT
remark: backfill

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

For Water Resources Department Use Only

Date: 2.23.00

Approved by: Mickael M. L...

Denied by: _____

Remarks: _____