

RECEIVED

AUG 31 1998

Oregon Water Resources Department

WATER RESOURCES DEPT
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 8/25/98

Bonded Well Constructor (name, license and mailing address): Frontier Bonding Service
1200 Westlake Ave. N. Suite 802, Seattle, Wa, 98109
Government Lot 1

(1) Location of Well: — 1/4 — 1/4 of Section 30, Township 17 S,
Range 15 E, Crook County.

Address at well site: 62500 County Line Rd
Bend, Or 97701

(2) Start Card Number(s): 68583

(3) Name and Address of Land Owner: Wayne P. & Susan R. Singhose
62500 County Line Rd Bend, Or 97701

(4) The distance to the nearest well, septic tank or drainfield (if water supply well):
nearest well 1/4 mile west

(5) The unusual conditions which necessitate this request: This well will be self dug
with an excavator since the water table is between 8' of the
surface and ends approx. 20' in depth. At this point hard
clay is encountered and no more water is available unless
one drills to 700'.

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

After the well has been dug a 48" galvanized culvert with
3/8" x 4" slots in the lower 12' will be installed. Then the well will
be filled with 12' drain field rock. The remaining area will
be filled with a clay based material.

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

see attached diagram.

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If verbal approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of verbal approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: *Wayne B. Singhose*

For Water Resources Department Use Only

Date: *8-24-98*

Approved by: *Bob Man*

Denied by: _____


Remarks: _____

RECEIVED

AUG 31 1998

CROSS SECTION OF WELL

WATER RESOURCES DEPT.
SALEM, OREGON



SCALE: 1/4" = 12"

total appr. 240 slots

PROPOSAL FOR WAYNE P. SINGHOSE