



# Oregon

Theodore R. Kulongoski, Governor

*ev*  
**Water Resources Department**

North Mall Office Building  
725 Summer Street NE, Suite A  
Salem, OR 97301-1271  
503-986-0900  
FAX 503-986-0904

May 2, 2005

BANDON WELL & PUMP CO INC  
JAMES A MACK # 1493  
47530 HWY 101  
BANDON OR 97411-9217

## FINAL ORDER

Dear Mr. Mack:

The Special Standard request you submitted for owner: James A. Gregory, Start Card number 172295, is approved for the following: You may install a water well to a depth of approximately 18 feet below ground surface. The well shall be sealed to a depth of at least 11.5 feet bgs (See OAR 690-210-0150). All other well construction requirements must be adhered to. Your Special Standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at [Kristopher.R.Byrd@wrdd.state.or.us](mailto:Kristopher.R.Byrd@wrdd.state.or.us).

Sincerely,

Kristopher Byrd  
Well Construction Program Coordinator  
Enforcement Section

enclosure

cc: Dave Cowgill, SW Region Well Inspector  
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.

**RECEIVED**

MAY 04 2005

WATER RESOURCES DEPT  
SALEM, OREGON**Oregon Water Resources Department****REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT  
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240**

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 158 12<sup>th</sup> Street NE, Salem OR 97301. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4/28/05 Oral approval date (if applicable): 4/28/05 ✓

Bonded Well Constructor (name, license #, and mailing address): Jim Mack, Sr #1493

Bandon Well & Pump Co 47530 Hwy 101 Bandon, OR. 97411

(1) Location of Well: NE 1/4 NE 1/4 of Section 13,  
Township 29S N/S, Range 15W E/W, Coos County  
Address at well site: 49034 Hwy 101 Bandon, OR. 97411

(2) Start Card Number(s)(for work to be done): 172295

(3) Name and Address of Land Owner: James A Gregory  
49034 Hwy 101 Bandon, OR. 97411


(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)  
125' +/-

(5) The unusual site conditions which necessitate this request: Shallow water  
bearing formation in area hand dug wells 11-15'  
Deep holes that have been drilled to 150' in marine clays  
produce no water

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Drill to bottom of water bearing formation and  
Seal as deep as practicle without shutting off  
water

- (7) Diagram showing the pertinent features of the proposed well design and construction: (attach additional pages if needed)



- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Jim Madh L. MGWC 1493