

RECEIVED

AUG 23 1996

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

WATER RESOURCES DEPT. SALEM, OREGON

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: August 20 19, 1996

Bonded Well Constructor (name, license and mailing address): Steven C. Bland

License #1592, 1169 Molalla Ave., Oregon City, OR 97045

(1) Location of Well: NE 1/4 NW 1/4 of Section 31, Township 2 South, Range 1 East, Clackamas County.

Address at well site: 5822 SW Walker Rd. Tualatin, OR

(2) Start Card Number(s): 87769

(3) Name and Address of Land Owner: Richard Copisarow & JM Crossley 18305 Lathlorine Way, Lake Oswego, OR 97034

(4) The distance to the nearest well, septic tank or drainfield (if water supply well): Over 100 feet


(5) The unusual conditions which necessitate this request: Two static water levels

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

Shale Trap with at least 20 feet of hole plug on top @ 150'

W-5m

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



RECEIVED

AUG 23 1996

WATER RESOURCES DEPT.
SALEM, OREGON

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If verbal approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of verbal approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Stewart C. Blum

For Water Resources Department Use Only

Date: 8-26-96

Approved by: [Signature] Denied by: _____

Remarks: _____