



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1271
503-986-0900
FAX 503-986-0904

April 14, 2005

Charles D. Nugent #664
36969 Rock Hill Road
Lebanon, OR 97355

Dear Chuck:

The special standard request you submitted for start card 172135 is approved for the following special standard: Bringing the well head a minimum of 12" above ground surface and leaving remainder of plumbing and electrical system in existing vault. Your special standard request form is enclosed for your information.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard, the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor and/or landowner is responsible for ensuring that a well constructed in a manner that protects the ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852 or by e-mail at: Juno.G.Pandian@wrp.state.or.us.

Sincerely,

JUNO PANDIAN, Manager
Enforcement Section

enclosure

cc: Kris Byrd, Well Construction Program Coordinator
Ken Wilcke, Water Well Inspector

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.

RECEIVED

APR 11 2005

Oregon Water Resources Department

WATER RESOURCES DEPT
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 158 12th Street NE, Salem OR 97301. Requests may also be considered by the appropriate Regional Manager.

VERBAL BY Jung
~~Handwritten signature~~

Date of request: 4-05 Oral approval date (if applicable): 4-05

Bonded Well Constructor (name, license #, and mailing address): CHARLES D. NUGST

36969 Rocc Hill Dr. Lebanon, OR #664

(1) Location of Well: NE 1/4 NE 1/4 of Section 33,

Township 11 ~~N~~^S Range 3 ~~E~~^W, LINN County

Address at well site: 33992 Seven Mile Lane
Albany, Ore.

(2) Start Card Number(s)(for work to be done): 172135

(3) Name and Address of Land Owner: Selmet Inc.

P.O. Box 689 Albany, Ore 97321

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
N/A.

(5) The unusual site conditions which necessitate this request: Well in VAULT
with ALL PLUMBING & electrical hook-ups BELOW
GROUND.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

VAULT is dry and well extension is 6" sch 40
P.U.C. Outside steel cover made to cover P.U.C.
AND BOLTED to VAULT BASE w/locking top.

W
UG

Remarks: Above grade well; lower portion of well in vault.

- (7) **Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)**

-
- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

