

FINAL ORDER
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.


Date of request: 1-13-00 Oral approval date (if applicable): 1-13-00

Bonded Well Constructor (name, license #, and mailing address): _____

- (1) Location of Well: NE 1/4 NE 1/4 of Section 33,
Township 18 N(S) Range 12 E W, Deschutes County.
Address at well site: 1402 NE Lafayette Ave
Bend OR 97701
- (2) Start Card Number(s): 124991
- (3) Name and Address of Land Owner: City of Bend
Po Box 431 Bend OR 97709
- (4) Distance to the nearest well, septic tank or drainfield (if water supply well): 200' +
- (5) The unusual conditions which necessitate this request: Extended Pumping
Chamber & better Sealing For dry
annulus
- (6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)
Over lap 10" liner in to 14" casing 2'
instead of 8' & use Sand Grout/Bent
chip Combo for Backfill between seals

W-CO, OT
remark: backfill

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

For Water Resources Department Use Only

Date: 2-23-00

Approved by: Michael McLa Denied by: _____

Remarks: Oral approval previously given.