

FINAL ORDER
Oregon Water Resources Department

RECEIVED

JAN 27 2000

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-299 WATER RESOURCES DEPT. SALEM, OREGON

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 1-27-00 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Bert Jones #514

29400 Santiam Hwy - Lebanon, OR 97355

(1) Location of Well: SW 1/4 SW 1/4 of Section 18,
Township 10 N/S Range 1 E/W Linn County.

Address at well site: 38875 NW 1st.
Scio, OR 97374

(2) Start Card Number(s): 128416 & 128418

(3) Name and Address of Land Owner: City of Scio

38875 NW 1st - Scio, OR 97374

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): _____

(5) The unusual conditions which necessitate this request: High volume water well. Cement is not filling well. It is spreading

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

Abandonment with cement & sand
grout.

W-am

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

RECEIVED

JAN 27 2000

WATER RESOURCES DEPT.
SALEM, OREGON

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

For Water Resources Department Use Only

Date: 2-1-00

Approved by: Michael L. M. [Signature] Denied by: _____

Remarks: _____