

STATE OF OREGON
WATER RESOURCES DEPARTMENTREQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,
NE, Salem, OR 97310.

Date:

2/5/97


Well Constructor:

American Well Drilling (Rod Erler) #663(1) Location of Well: SW 1/4 SW 1/4 of Section 29,Township 1-S, Range 4-E, Clack County.Address at well site or nearest known address: 30686 SE Wellbill Rd.
Boonville, OR. 97009

(2) Name and address of Landowner:

SAME AS ABOVE(3) The distance to the nearest well and septic drainfield: 100 ft. +(4) The unusual conditions existing at the well site: ~~none~~ ~~none~~ ~~none~~I had a weld broke at 29'(5) The proposed construction methods that the well constructor or landowner
constructing the well believes will be adequate for his particular well:Weld a outer sleeve on the bottom of the 10" casing
& set it over the casing as it is in the hole. then cement
it in place.w-ca
remark: repair

- (6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



(Signed) Rod Galt
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date:

2-9-97

Approved by:

[Signature]

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.

84150