

STATE OF OREGON  
COUNTY OF DESCHUTES  
CERTIFICATE OF WATER RIGHT

THIS CERTIFICATE ISSUED TO

CITY OF REDMOND  
875 SE VETERANS WAY  
REDMOND, OR 97756

confirms the right to use the waters of 4 WELLS in the Deschutes Basin for MUNICIPAL USE.

This right was perfected under Permit G-6793. The date of priority is MARCH 27, 1975. The amount of water to which this right is entitled is limited to an amount actually used beneficially, and shall not exceed 3.3 CUBIC FEET PER SECOND, BEING: 1.70 CFS FROM WELL 1, 2.08 FROM WELL 2, 2.64 CFS FROM WELL 4, AND 3.30 CFS FROM WELL 5, IN ANY COMBINATION, or its equivalent in case of rotation, measured at the well.

The wells are located as follows:

WELL	Twp	Rng	Mer	Sec	Q-Q	Measured Distances
1	15 S	13 E	WM	9	NE NW	SOUTH 83 DEGREES 30 MINUTES WEST, 546 FEET FROM N1/4 CORNER, SECTION 9
2 (ORIGINAL)	15 S	13 E	WM	16	NW SW	NORTH 27 DEGREES 24 MINUTES EAST, 1800 FEET FROM SW CORNER, SECTION 16
5	15 S	13 E	WM	20	NE NE	SOUTH 5 DEGREES 48 MINUTES WEST, 1200 FEET FROM NE CORNER, SECTION 20
4	15 S	13 E	WM	20	SE SW	NORTH 82 DEGREES 41 MINUTES WEST, 3945 FEET FROM SE CORNER, SECTION 20

A description of the place of use to which this right is appurtenant is as follows:

ALL  
SECTION 4

E½ E½  
SECTION 8

ALL  
SECTION 9

**SUPERSEDED BY**  
**CERT. NO. 89413**

**NOTICE OF RIGHT TO PETITION FOR RECONSIDERATION OR JUDICIAL REVIEW**

This is an order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080, you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied. In addition, under ORS 537.260 any person with an application, permit or water right certificate subsequent in priority may jointly or severally contest the issuance of the certificate at any time before it has issued, and after the time has expired for the completion of the appropriation under the permit, or within three months after issuance of the certificate.

NW<sup>1</sup>/<sub>4</sub> NW<sup>1</sup>/<sub>4</sub>  
S<sup>1</sup>/<sub>2</sub> NW<sup>1</sup>/<sub>4</sub>  
SW<sup>1</sup>/<sub>4</sub>  
SECTION 10

W<sup>1</sup>/<sub>2</sub>  
NW<sup>1</sup>/<sub>4</sub> SE<sup>1</sup>/<sub>4</sub>  
S<sup>1</sup>/<sub>2</sub> SE<sup>1</sup>/<sub>4</sub>  
SECTION 15

ALL  
SECTION 16

E<sup>1</sup>/<sub>2</sub> E<sup>1</sup>/<sub>2</sub>  
SECTION 17

SE<sup>1</sup>/<sub>4</sub> SW<sup>1</sup>/<sub>4</sub>  
E<sup>1</sup>/<sub>2</sub> SE<sup>1</sup>/<sub>4</sub>  
SW<sup>1</sup>/<sub>4</sub> SE<sup>1</sup>/<sub>4</sub>  
SECTION 19

E<sup>1</sup>/<sub>2</sub> NE<sup>1</sup>/<sub>4</sub>  
SW<sup>1</sup>/<sub>4</sub> NE<sup>1</sup>/<sub>4</sub>  
S<sup>1</sup>/<sub>2</sub>  
SECTION 20

N<sup>1</sup>/<sub>2</sub> NE<sup>1</sup>/<sub>4</sub>  
NW<sup>1</sup>/<sub>4</sub>  
N<sup>1</sup>/<sub>2</sub> SW<sup>1</sup>/<sub>4</sub>  
SW<sup>1</sup>/<sub>4</sub> SW<sup>1</sup>/<sub>4</sub>  
SECTION 21

ALL  
SECTION 22

W<sup>1</sup>/<sub>2</sub> E<sup>1</sup>/<sub>2</sub>  
W<sup>1</sup>/<sub>2</sub>  
SECTION 23

NW<sup>1</sup>/<sub>4</sub> NE<sup>1</sup>/<sub>4</sub>  
NW<sup>1</sup>/<sub>4</sub>  
SECTION 26

N<sup>1</sup>/<sub>2</sub>  
SECTION 27

N<sup>1</sup>/<sub>2</sub> NE<sup>1</sup>/<sub>4</sub>  
SE<sup>1</sup>/<sub>4</sub> NE<sup>1</sup>/<sub>4</sub>  
SECTION 29

NE<sup>1</sup>/<sub>4</sub> NW<sup>1</sup>/<sub>4</sub>  
SECTION 30  
TOWNSHIP 15 SOUTH, RANGE 13 EAST, W.M.

TOWNSHIP 15 SOUTH, RANGE 13 EAST, W.M.

The quantity of water diverted at the new points of appropriation (wells), together with that diverted at the old points of appropriation, shall not exceed the quantity of water lawfully available at the original points of appropriation.

The water user shall maintain headgates, in-line flow meters, weirs, or other suitable devices for measuring and recording the quantity of water diverted and keep a complete record of the amount of ground water withdrawn.

Water shall be acquired from the same aquifer as the original points of appropriation.

The well shall be maintained in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

Water may be applied to lands which are not specifically described above, provided the holder of this right complies with ORS 540.510(3).

The use of water shall be limited when it interferes with any prior surface or ground water rights.

Issued           MAY 14 2010          .



Dwight W. French  
Administrator Water Rights and Adjudications, for  
Phillip C. Ward, Director  
Oregon Water Resources Department