

STATE OF OREGON
COUNTY OF CROOK
CERTIFICATE OF WATER RIGHT

THIS CERTIFICATE ISSUED TO

VITESSE LLC
C/O FACEBOOK INC.
1601 S CALIFORNIA AVE
PALO ALTO CA 94304

confirms the right to the use of water perfected under the terms of Permit G-17582. The amount of water used to which this right is entitled is limited to the amount used beneficially, and shall not exceed the amount specified, or its equivalent in the case of rotation, measured at the point of diversion from the source. The specific limits and conditions of the use are listed below.

APPLICATION FILE NUMBER: G-17338

SOURCE OF WATER: WELL 1 (CROO 53878), WELL 2 (CROO 53726/CROO 53886), AND WELL 3 IN CROOKED RIVER BASIN

PURPOSE OR USE: INDUSTRIAL/MANUFACTURING

MAXIMUM RATE: 0.758 CUBIC FOOT PER SECOND (CFS), FURTHER LIMITED TO 0.758 CFS FROM WELL 1 (CROO 53878), 0.12 CFS FROM WELL 2 (CROO 53726/CROO 53886), AND 0.758 CFS FROM WELL 3, MAXIMUM CUMULATIVE TOTAL NOT TO EXCEED 0.758 CFS, FURTHER LIMITED TO 174.0 ACRE FEET PER YEAR

PERIOD OF USE: JANUARY 1 THROUGH DECEMBER 31

DATE OF PRIORITY: MARCH 31, 2010

The wells are located as follows:

Twp	Rng	Mer	Sec	Q-Q	Measured Distances
15 S	15 E	WM	2	SE SE	WELL 1 (CROO 53878) – ORIGINAL – 128 FEET NORTH AND 139 FEET WEST FROM SE CORNER, SECTION 2
15 S	15 E	WM	2	SE SE	WELL 2 (CROO 53726/CROO53886) – ORIGINAL – 203 FEET NORTH AND 139 FEET WEST FROM SE CORNER, SECTION 2
15 S	15 E	WM	2	SE SE	WELL 3 – NEW – 104 FEET NORTH AND 127 FEET WEST FROM SE CORNER, SECTION 2

NOTICE OF RIGHT TO PETITION FOR RECONSIDERATION OR JUDICIAL REVIEW

This is an order in other than a contested case. This order is subject to judicial review under ORS 183.484 and ORS 536.075. Any petition for judicial review must be filed within the 60-day time period specified by ORS 183.484(2). Pursuant to ORS 183.484, ORS 536.075 and OAR 137-004-0080, you may petition for judicial review and petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied. In addition, under ORS 537.260 any person with an application, permit or water right certificate subsequent in priority may jointly or severally contest the issuance of the certificate within three months after issuance of the certificate.

A description of the place of use is as follows:

Twp	Rng	Mer	Sec	Q-Q
15 S	15 E	WM	1	NE SW
15 S	15 E	WM	1	NW SW
15 S	15 E	WM	1	SW SW

Twp	Rng	Mer	Sec	Q-Q
15 S	15 E	WM	1	SE SW
15 S	15 E	WM	2	NE SE
15 S	15 E	WM	2	SE SE

Measurement, recording and reporting conditions for Well 1 (CROO 53878) and Well 2 (CROO 53726/CROO 53886):

- A. The water user shall maintain the totalizing flow meter at each point of appropriation in good working order. The water user shall keep a complete record of the amount of water used each month, and shall submit a report which includes the recorded water-use measurements to the Department annually or more frequently as may be required by the Director. Further, the Director may require the water user to report general water-use information, including the place and nature of use of water under the right.
- B. The water user shall allow the watermaster access to the meters; where a meter is located within a private structure, the watermaster shall request access upon reasonable notice.

Measurement, recording and reporting condition for Well 3:

- A. The water user shall maintain the totalizing flow meter or other suitable measuring device as approved by the Director in good working order.
- B. The water user shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.

The Department requires the water user to obtain, from a qualified individual (see below), and report annual static water levels for each well on the right. The static water level shall be measured in the month of March. Reports shall be submitted to the Department within 30 days of measurement. The water user shall report annual March static water-level measurements whether or not the well is used. The Director may require the user to obtain and report additional water levels each year if more data are needed to evaluate the aquifer system.

All measurements shall be made by a certified water rights examiner, registered professional geologist, registered professional engineer, licensed well constructor or pump installer licensed by the Construction Contractors Board. Measurements shall be submitted on forms provided by, or specified by, the Department. Measurements shall be made with equipment that is accurate to at least the standards specified in OAR 690-217-0045. The Department requires the individual performing the measurement to:

- A. Associate each measurement with an owner’s well name or number and a Department well log ID; and
- B. Report water levels to at least the nearest tenth of a foot as depth-to-water below ground surface; and
- C. Specify the method of measurement; and
- D. Certify the accuracy of all measurements and calculations reported to the Department.

The water user shall discontinue use of, or reduce the rate or volume of withdrawal from, the well(s) if any of the following events occur:

- A. Annual water-level measurements reveal an average water-level decline of three or more feet per year for five consecutive years; or
- B. Annual water-level measurements reveal a water-level decline of 15 or more feet in fewer than five consecutive years; or
- C. Annual water-level measurements reveal a water-level decline of 25 or more feet; or
- D. Hydraulic interference leads to a decline of 25 or more feet in any neighboring well with senior priority.

The reference levels against which future measurements will be compared is 322.51 feet below ground surface for Well 1 (CROO 53878), 351.37 feet below ground surface for Well 2 (CROO 53726/CROO 53886), and 359.46 feet below ground

surface for Well 3.

The period of restricted use shall continue until the water level rises above the decline level which triggered the action or until the Department determines, based on the water user's and/or the Department's data and analysis, that no action is necessary because the aquifer in question can sustain the observed declines without adversely impacting the resource or senior water rights. The water user shall in no instance allow excessive decline, as defined in Commission rules, to occur within the aquifer as a result of use under this right. If more than one well is involved, the water user may submit an alternative measurement and reporting plan for review and approval by the Department.

Dedicated Measuring Tube: Wells with pumps shall be equipped with an unobstructed, dedicated measuring tube pursuant to figure 200-5 in OAR 590-200.

The water user shall ensure that the well has been assigned an OWRD Well Identification Number (Well ID tag), which shall be permanently attached to the well. The Well ID shall be used as a reference in any correspondence regarding the well, including any reports of water use, water level, or pump test data.

Any effluents or return flows from use under this right shall not interfere with other beneficial uses of water.

Ground Water Mitigation Conditions:

Mitigation Obligation: 174.0 acre-feet of mitigation water in the Crooked River Zone of Impact (anywhere in the Crooked River Basin above river mile 13.8)

Mitigation Source: 174.0 mitigation credits, associated with Mitigation Project MP-25 (Transfer T-9687), Mitigation Project MP-28 (Transfer T-9829), and Mitigation Project MP-124 (Transfer T-10730).

Mitigation water must be legally protected instream for instream use within the Crooked River Zone of Impact for the life of the certificate and subsequent certificate(s). Regulation of the use and/or cancellation of the certificate or subsequent certificate(s) will occur if the required mitigation is not maintained.

The water user shall provide additional mitigation if the Department determines that average annual consumptive use of the subject appropriation has increased beyond the originally mitigated amount.

If mitigation is from a secondary right for stored water from a storage project not owned or operated by the water user, the use of water under this right is subject to the terms and conditions of a valid contract or satisfactory replacement, a copy of which must be on file in the records of the Water Resources Department.

Failure to comply with these mitigation conditions shall result in the Department regulating the ground water certificate, or subsequent certificate(s), and proposing to cancel the ground water certificate or subsequent certificate(s).

Scenic Waterway Condition:

Use of water under authority of this right may be regulated if analysis of data available after the right is issued discloses that the appropriation will measurably reduce the surface water flows necessary to maintain the free-flowing character of a scenic waterway in quantities necessary for recreation, fish and wildlife in effect as of the priority date of the right or as those quantities may be subsequently reduced. However, the use of ground water allowed under the terms of this right will not be subject to regulation for Scenic Waterway flows so long as mitigation as required herein is maintained.

Failure to comply with any of the provisions of this right may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the right.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this right, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

The wells shall be maintained in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge

adequate to determine the water level elevation in the well at all times.

Where two or more water users agree among themselves as to the manner of rotation in the use of water and such agreement is placed in writing and filed by such water users with the watermaster, and such rotation system does not infringe upon such prior rights of any water user not a party to such rotation plan, the watermaster shall distribute the water according to the agreement.

The Director may require water level or pump test results every ten years.


This right is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The combined quantity of water diverted at the new point of appropriation (Well 3), together with that diverted at the old points of appropriation (Well 1 and Well 2), shall not exceed the quantity of water lawfully available at the original points of appropriation.

The right to the use of the water for the above purpose is restricted to beneficial use on the place of use described.

Issued SEP 11 2019.



Dwight French
Water Right Services Division Administrator, for
Thomas M. Byler, Director
Oregon Water Resources Department