

RECEIVED

SEP 10 1986

WATER RESOURCES DEPT
SALEM, OREGON

Application No. 68855
Permit No. 49929

14", 160 p.s.i. ABS pipe
siphon line to storage tank

N. 283'
E. 249' FROM THE
NW 1/4 CORNER
Sec. 6, T. 3N, R. 10W, W.M.

unnamed
creek
3 wellpoints
buried in sand and
gravel

FIRE MT SCHOOL

1" PVC delivery
to FMS

NW 1/16 COR.
SECTION 6
T. 3.N., R. 10.W, W.M.

Tallman Water System
Falcon Cove, Arch Cape, OR

Scale 1" = 100'

1200 gal. unpressurized holding tank
3/4 h.p. pump to reprime siphon
260 gal. holding tank, 3/4 hp pump,
treatment system, 2-120 gallon
pressurized holding tanks

2" PVC gravity
feed line to Benton lot

TIDE AVE

FALCON COVE RD.

ELK FLAT RD.

Benton

