

RECEIVED  
JULY 1953  
STATE ENGINEER  
SALEM, OREGON

Registration No. GR-2017

Certificate No. GR-1914

# Registration Statement

## OF CLAIMANT OF RIGHT TO APPROPRIATE GROUND WATER

TO THE STATE ENGINEER OF OREGON:

I, Mountainside Cemetary Assoc.  
of P.O. Box 95, Newberg, Ora. County of Washington  
(Mailing address)

State of Oregon, do hereby make application for a certificate of registration as evidence of a right to appropriate ground water.

1. Source from which water is withdrawn is Pump Well  
(Flowing well, pump well, infiltration trench, or tunnel)

2. Location is: Nine miles N. of Newberg, Ora.  
(Approximate distance and direction from nearest city or town)

and is more particularly described as follows:

Be SW 1/4 sec 16  
1125' N. and 800' E. from SW corner Section 16  
(Give distance and bearing to corner of section or other legal subdivision)

being within NE 1/4 SW 1/4 SW 1/4 of Sec. 16, Twp. 2 S, Rge. 2 WNW,  
(Smallest legal subdivision) (N. or S.) (E. or W.)

or (b) within limits of recorded platted property, town or city: \_\_\_\_\_

in Lot \_\_\_\_\_, Block \_\_\_\_\_ of \_\_\_\_\_  
(Name of plat or addition)

County of \_\_\_\_\_  
(If within city or town, give name)

3. Construction Work was begun on 1953; was completed on June 9, 1953  
(Date) (Date)

and the ground water claimed was first used for the purposes set out below on Sept 15, 1953  
(Date)

since which time the water has been used intermittently  
(Continuous or intermittently)

from April 15 to Oct 1  
(Date) (Date)

4. Quantity of water claimed and used is 36 gallons per minute; \_\_\_\_\_ acre feet per year.

5. Purpose or Purposes for which water is used Irrigation of Cemetary lawn  
(Domestic, irrigation, municipal, manufacturing, industrial, etc.)

6. Description of Well: Depth 231 feet. Type drilled  
(Dug or drilled)  
diameter 6" 1 1/2" inches. Elevation of ground at well site 200 feet, mean sea level.  
(As near as known)  
Depth to water table 87 feet.

7. Capacity of Well: 39 g.p.m. with 155 feet drawdown.  
\_\_\_\_\_ g.p.m. with \_\_\_\_\_ feet drawdown.

Date of test June 9, 1953

If Flowing Well: Measured discharge \_\_\_\_\_ g.p.m. on \_\_\_\_\_  
(Date)


Shut-in pressure at ground surface \_\_\_\_\_ lbs. per sq. in. on \_\_\_\_\_  
(Date)

Water is controlled by \_\_\_\_\_  
(Cap, valve, etc.)





Township 2S Range 2W W.M.  
North



Locate well and acreage of irrigated land on plat.  
Scale: 2" = 1 Mile

STATE OF OREGON

County of \_\_\_\_\_ } ss.

I, George Wendland, being first duly sworn, do hereby certify that I have read the foregoing Registration Statement and that all of the items therein contained are true to the best of my knowledge and belief.

George Wendland Sec. Treas.  
(Signature of Registrant)

Subscribed and sworn to before me this 7th day of July, 1958.

My commission expires 12th June 1961

Wm. S. Bartholomew  
(Notary Public)

(SEAL)

**CERTIFICATE OF REGISTRATION**

STATE OF OREGON

County of Marion } ss.

This is to certify that the foregoing Registration Statement was received in the office of the State Engineer on the 10th day of July, 1958, at 8.00 o'clock A. M. and has been duly recorded in said office in Book No. 9 of Registration Statements on page GR-1914

Witness my hand this 9th day of February, 1959.

Laura A. Standen  
(State Engineer)

By \_\_\_\_\_  
(Deputy)

\$1500

GR - 1914