

Registration Statement

OF CLAIMANT OF RIGHT TO APPROPRIATE GROUND WATER

TO THE STATE ENGINEER OF OREGON:

I, THE TERMINAL ICE & COLD STORAGE COMPANY

of (General office) 320 N. W. Hoyt Street, Portland, Ore. County of Multnomah

(Mailing address)

State of Oregon, do hereby make application for a certificate of registration as evidence of a right to appropriate ground water.

1. Source from which water is withdrawn is Pump well
(Flowing well, pump well, infiltration trench, or tunnel)

2. Location is: A little south of east of the City of Woodburn, Marion County, Ore.
(Approximate distance and direction from nearest city or town)
 and is more particularly described as follows: 1000 ft. east & 200 feet south from W/4 corner Section 17

(a) See map and detailed statement attached.
(Give distance and bearing to corner of section or other legal subdivision)

being within NW 1/4 of SW 1/4 of Sec. 17, Twp. 5 South, Rge. 1 West
(Smallest legal subdivision) (N. or S.) (E. or W.)

or (b) within limits of recorded platted property, town or city: _____

in Lot _____, Block _____ of _____
(Name of plat or addition)

County of _____
(If within city or town, give name)

3. Construction Work was begun on About April 4, 1952 was completed on about May 9, 1952
(Date) (Date)

and the ground water claimed was first used for the purposes set out below on during first part of June 1952
(Date)

since which time the water has been used continuously
(Continuously or intermittently)

from June 1952 to _____
(Date) (Date)

4. Quantity of water claimed and used is 150 gallons per minute; _____ acre feet per year.

5. Purpose or Purposes for which water is used Principally for industrial use for the operation of refrigeration equipment (coolant, for heat transfer) and general operation and maintenance of cold storage warehouses and for use for related operations such as food processing, for drinking fountains, wash basins, toilets, etc. and for domestic use in a dwelling on the premises. Also used for irrigating the lawn and garden in the immediate area of the warehouse building and dwelling.

6. Description of Well: Depth 171 feet. Type Drilled
(Dug or drilled)
 diameter ten (10) inches. Elevation of ground at well site Approx. 100 feet, mean sea level.
(As near as known)

Depth to water table 23 feet, (Static water level, 73 ft., at time of test, May 9, 1952)

7. Capacity of Well: 200 g.p.m. with 19 feet drawdown.
300 g.p.m. with 23 feet drawdown
400 g.p.m. with 38 feet drawdown
490 g.p.m. with 46 feet drawdown

Date of test May 9, 1952

If Flowing Well: Measured discharge _____ g.p.m. on _____
(Date)

Shut-in pressure at ground surface _____ lbs. per sq. in. on _____
(Date)

Water is controlled by _____
(Cap, valve, etc.)

8. Casing: (Give diameter, commercial specifications and depth below ground surface of each casing size.)

Ten (10) inch diameter (Standard pipe) from zero to 167 feet
 inch diameter from to feet
 inch diameter from to feet
 inch diameter from to feet

Describe and show depth of shoe, plug, adapter, liner or other details: Shoe was fabricated from a piece 12 1/2" outside diameter by 12" long, fitted to the bottom end of the casing, included in 167 feet shown for the depth of the casing.

9. Perforated Casings or Screens:

Perforated casing (3/8" wide by 1 1/2" long - 40 per foot) from 129 ft. to 136 ft.
(Number per foot and size of perforations, or describe screen)
 Perforated casing (3/8" wide by 1 1/2" long - 40 per foot) from 148 ft. to 167 ft.
 from to
 from to

10. Log of Well: (Describe each stratum or formation clearly, indicate if water bearing, and give thickness and depth as indicated.)

MATERIAL	Thickness (Feet)	Depth to Bottom (Feet)
Brown silty clay	Surface to	42 ft.
Blue silt	42 ft. to	90 ft.
Sticky blue clay	90 ft. to	92 ft.
Sandy clay	92 ft. to	114 ft.
Sand with traces of pea gravel	114 ft. to	129 ft.
Sand and gravel-water bearing	129 ft. to	131 ft.
Loose gravel - water bearing	131 ft. to	135 ft.
Sandy clay	135 ft. to	145 ft.
Sand and pea gravel	145 ft. to	158 ft.
Large, loose gravel - water bearing	158 ft. to	163 ft.
Blue clay	163 ft. to	171 ft.

If log of well is not available, give name and address of driller.

11. Infiltration Trench: Covered or open

Dimensions: Length ft. Minimum depth ft. Maximum depth ft.

Bottom width ft. Discharge g.p.m. Date of test

12. Tunnel: Type of lining 7

Dimensions:
(Length, course, and cross sectional size)

Position of water bearing stratum with reference to portal of tunnel

Log of tunnel: (Preceding table for log of well may be used, if desired; Give footage from portal and character of materials, as pertinent.)

13. Pumping Equipment:


- One - Layne & Bowler 11 stage 8" TLH,
- (a) Pump oil lubricated deep well turbine pump Capacity 150 g.p.m. at 270 ft. head.
(Make, type and size)
- (b) Motor One - 15 H.P., 3 Phase, 1800 RPM, SCU Type, U.S. 220/110 Volt.
(Type and horsepower)
Vertical hollow shaft motor, with reverse protection clutch.

14. Location of area irrigated or to be irrigated, or place of use if for purposes other than irrigation.

Township North or South	Range E. or W. of Willamette Meridian	Section	Forty-acre Tract	Number Acres To Be Irrigated	Date of Reclamation
The primary purpose or use for which this well was constructed was that of the operation of cold storage warehouse facilities and related purposes such as food processing. The irrigation of the lawn, shrubbery, etc., in the immediate area of the buildings is incidental to and a part of the overall operation and maintenance of the facilities and premises.					

15. If the ground water supply is supplemental to an existing water supply, identification of any application for a permit, permit, certificate or adjudicated right to appropriate water made or held by the registrant.

Township 55 Range 1W W.M.
North



See map and detailed description attached hereto.

Locate well and acreage of irrigated land on plat.

Scale: 2" = 1 Mile

STATE OF OREGON

County of Multnomah

ss.

I, Alex. P. Olsson, Vice Pres. Treas., being first duly sworn, do hereby certify that I have read the foregoing Registration Statement and that all of the items therein contained are true to the best of my knowledge and belief.

THE TERMINAL ICE & COLD STORAGE COMPANY

By [Signature]
(Signature of Registrant)

Subscribed and sworn to before me this 29th day of July, 1958.

My commission expires May 13, 1960

[Signature]
(Notary Public)

(SEAL)

CERTIFICATE OF REGISTRATION

STATE OF OREGON

County of Marion

ss.

This is to certify that the foregoing Registration Statement was received in the office of the State Engineer on the 31 day of July, 1958, at 8:00 o'clock A.M. and has been duly recorded in said office in Book No. 13 of Registration Statements on page GR-3124.

Witness my hand this 16th day of June, 1959

[Signature]
(State Engineer)

By _____ (Deputy)

GR - 3124

20.00