

STATE OF OREGON

COUNTY OF POLK

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

PERRYDALE DOMESTIC WATER ASSOCIATION  
11475 WEST PERRYDALE ROAD  
AMITY, OREGON 97101

503-835-7221

to use the waters of WELL 2A in the WILLAMETTE RIVER BASIN for QUASI-MUNICIPAL USES.

This Permit is issued approving Application G-11935. The date of priority is JUNE 16, 1989. The use is limited to not more than 60.0 GALLONS PER MINUTE, or its equivalent in case of rotation, measured at the well.

The well is located as follows:

SE 1/4 SW 1/4, SECTION 29, T 6 S, R 3 W, W.M.; 668 FEET NORTH AND 2953 FEET EAST FROM SW CORNER, DLC 54.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the proposed place of use under the permit is as follows:

SECTIONS 29, 30 AND 32  
TOWNSHIP 6 SOUTH, RANGE 3 WEST, W.M.

SECTIONS 30, 31, 32 AND 33  
TOWNSHIP 5 SOUTH, RANGE 4 WEST, W.M.

SECTIONS 4, 5, 6, 7, 8 AND 9  
SECTIONS 16, 17, 18, 19, 20, 21, 22 AND 23  
SECTIONS 25, 26, 28, 29, 30, 31, 32 AND 33  
W 1/2 SECTION 27 AND W 1/2 SECTION 34  
TOWNSHIP 6 SOUTH, RANGE 4 WEST, W.M.

W 1/2 SECTIONS 3, 4, 5, 6, 7, 8, 9 AND 10  
NW 1/4 SECTION 15  
N 1/2 SECTIONS 16 AND 17  
NE 1/4 SECTION 18  
TOWNSHIP 7 SOUTH, RANGE 4 WEST, W.M.

S 1/2 AND S 1/2 N 1/2 SECTIONS 25, 26, 27, 28, 29 AND 30  
SECTIONS 31, 32, 33, 34, 35 AND 36  
TOWNSHIP 5 SOUTH, RANGE 5 WEST, W.M.

ALL  
TOWNSHIP 6 SOUTH, RANGE 5 WEST, W.M.

SECTIONS 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11 AND 12  
SECTIONS 15, 16, 17, 18 AND 19  
TOWNSHIP 7 SOUTH, RANGE 5 WEST, W.M.

SECTION 1  
S 1/2 SECTIONS 2, 3 AND 4  
SECTIONS 9, 10, 11, 12, 13, 14, 15 AND 16  
SECTIONS 21, 22, 23, 24, 25, 26, 27 AND 28  
SECTIONS 33, 34, 35 AND 36  
TOWNSHIP 6 SOUTH, RANGE 6 WEST, W.M.

SECTIONS 1, 2, 3 AND 4  
 SECTIONS 11, 12, 13 AND 14  
 SECTIONS 23 AND 24  
 TOWNSHIP 7 SOUTH, RANGE 6 WEST, W.M.

The Perrydale Domestic Water Association shall submit a Water Management Plan approved by the Resource Management Division of the Water Resources Department within nine months of permit issuance. The plan shall specify the Association's steps to obtain and maintain high water use efficiency and the ability to manage water use during periods of water shortage.

The Perrydale Domestic Water Association shall submit a Water Development Master Plan approved by the Resource Management Division of the Water Resources Department within two years of permit issuance. The plan shall include the steps the Association intends to pursue to obtain a long-term water supply from a source other than basalt ground water aquifers in the area.

The Ground Water/Hydrology Section of the Water Resources Department shall determine the initial water levels by June 1, 1990, and subsequent water levels from which the following cited declines are referenced. As much as possible, those levels shall reflect annual high water levels which are usually found in the winter or spring of each year. Use of water as allowed herein shall not begin until the initial levels are determined or until June 1, 1990, whichever occurs first.

Use of water under this permit shall be regulated if the well displays:

- A. an average water level decline of three (3) or more feet per year for five consecutive years, or
- B. a water level decline of fifteen (15) or more feet in fewer than five consecutive years, or
- C. a water level decline of twenty-five (25) feet or more.

Use of water from any well under this permit shall be regulated if any such well creates an hydraulic interference decline of twenty-five (25) or more feet in any neighboring well with a senior priority which provides water for an authorized use.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevations in the well at all times. The permittee shall install and maintain an in-line flow meter according to manufacturers instructions and subject to watermaster approval. Complete records of the amounts of ground water withdrawn shall be submitted annually on a form provided by the Department.

The Association shall submit annual complications of monthly static water level measurements to the Department for review. After review of these data, the Department may modify this data requirement.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Ground Water/Hydrology Section of the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Actual construction work shall begin on or before MARCH 12, 1991, and shall be completed on or before October 1, 1991. Complete application of the water shall be made on or before October 1, 1992.

*B extended to 10-1-92*  
*Be " " 10-1-97*

