

STATE OF OREGON

COUNTY OF MARION

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

VALENTINE MILLER
8626 WASASH DRIVE
BROOKS, OREGON 97305

503-792-3380

to use the waters of NORTH AND SOUTH WELL in the PUDDING RIVER BASIN for IRRIGATION OF 91.8 ACRES.

This permit is issued approving Application G-12725. The date of priority is DECEMBER 6, 1991. The use is limited to not more than 1.15 CUBIC FEET PER SECOND (CFS), BEING 0.54 CFS FROM NORTH WELL AND 0.61 CFS FROM SOUTH WELL, or its equivalent in case of rotation, measured at the wells.

The wells are located as follows:

NW 1/4 SE 1/4, SECTION 36, T 5 S, R 2 W, W.M., SW 1/4 NW 1/4, SECTION 1, T 6 S, R 2 W, W.M.; NORTH WELL - 300 FEET SOUTH AND 925 FEET EAST FROM SE CORNER, DLC 46, SOUTH WELL - 1580 FEET NORTH AND 1200 FEET WEST FROM SW CORNER, DLC 62.

The amount of water used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second (or its equivalent) and 2.5 acre-feet for each acre irrigated during the irrigation season of each year.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the proposed place of use under this permit is as follows:

NE 1/4 SW 1/4 6.2 ACRES
SE 1/4 SW 1/4 20.4 ACRES
NW 1/4 SE 1/4 13.9 ACRES
SW 1/4 SE 1/4 18.8 ACRES

SECTION 36

TOWNSHIP 5 SOUTH, RANGE 2 WEST, W.M.

NE 1/4 NW 1/4 16.8 ACRES
NW 1/4 NW 1/4 15.7 ACRES

SECTION 1

TOWNSHIP 6 SOUTH, RANGE 2 WEST, W.M.

The source of water under this permit is limited to the Black Sand groundwater reservoir located approximately 150 to 250 feet below land surface.

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times. When required by the department, the permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Actual construction work shall begin on or before February 18, 1993, and shall be completed on or before October 1, 1993. Complete application of the water shall be made on or before October 1, 1995.

to 10-1-95

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

This permit is for beneficial use of water without waste. The water user is advised that new regulations may require use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

Issued this date, FEBRUARY 18, 1992.

/s/ WILLIAM H. YOUNG

Water Resources Department
William H. Young
Director