

STATE OF OREGON

COUNTY OF MULTNOMAH

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

PORTLAND STATE UNIVERSITY  
C/O CHUCK CARTER, SUPERVISOR-PHYSICAL PLANT OPERATIONS 503-725-4949  
630 S.W. MILL  
PORTLAND, OREGON 97207

to use the waters of WELL 1 & WELL 3 in the WILLAMETTE RIVER BASIN for INDUSTRIAL USE.

This permit is issued approving Application G-12870. The date of priority is APRIL 10, 1992. The use is limited to not more than 2.96 CUBIC FEET PER SECOND (CFS), BEING 1.56 CFS FROM WELL 1 AND 1.40 CFS FROM WELL 3, or its equivalent in case of rotation, measured at the wells. The use of water for air conditioning in excess of 5000 gallons per day shall be subsequent in priority to future beneficial consumptive use unless a two well system is constructed and all water wasted from the system recharged to the same ground water reservoir from which it was withdrawn.

The wells are located as follows:

SE 1/4 NE 1/4, SECTION 4, T 1 S, R 1 E, W.M.; 2620 FEET SOUTH AND 365 FEET WEST, 2300 FEET SOUTH AND 170 FEET WEST, BOTH FROM NE CORNER, SECTION 4.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the proposed place of use under this permit is as follows:

SE 1/4 NE 1/4  
SECTION 4  
TOWNSHIP 1 SOUTH, RANGE 1 EAST, W.M.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

The PERMITTEE shall develop a plan to monitor and report the impact of water use under this permit on water levels within the aquifer that provides water to the permitted well(s). The plan shall be submitted to the Department within one year of the date the permit is issued and shall be subject to the approval of the Department. At a minimum, the plan shall include a program to periodically measure static water levels within the permitted well(s) or an adequate substitute such as water levels in nearby wells. The plan shall also stipulate a reference water level against which any water-level declines will be compared. If a well listed on this permit displays a total static water-level decline of 25 or more feet over any period of years, as compared to the reference level, then the PERMITTEE shall discontinue use of, or reduce the rate or volume of withdrawal from, the well(s). Such action shall be taken until the water level recovers to above the 25-foot decline level or until the Department determines, based on the PERMITTEES or the Department's data and analysis, that no action is necessary because the aquifer in question can sustain the observed declines without adversely impacting the resource or senior water rights. The PERMITTEE shall in no instance allow excessive decline to occur within the aquifer as a result of use under this permit.

## Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a meter or other suitable measuring device as approved by the Director. The permittee shall maintain the meter or measuring device in good working order.
- B. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.
- C. The Director may require the permittee to keep and maintain a record of the amount (volume) of water used and may require the permittee to report water use on a periodic schedule as established by the Director. In addition the Director may require the permittee to report general water use information, the periods of water use and the place and nature of use of water under the permit. The Director may provide an opportunity for the permittee to submit alternative reporting procedures for review and approval.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Actual construction work shall begin on or before November 18, 1995 and shall be completed on or before October 1, 1996. Complete application of water shall be made on or before October 1, 1997.

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

This permit is for beneficial use of water without waste. The water user is advised that new regulations may require use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

The Director of the Water Resources Department has found that the proposed use of water described by this permit, as conditioned, will not impair or be detrimental to the public interest.

Issued this date, November 18, 1994.

/s/ MARTHA O. PAGEL

Water Resources Department  
Martha O. Pagel  
Director

Application G-12870 Water Resources Department PERMIT G-11831  
Basin 2 Volume 25 Willamette River N 1/2 & Misc. District 1  
Mgmt. Codes 4HG