

STATE OF OREGON

COUNTY OF JACKSON

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

CHERYL L SHAW
980 KUBLI RD
GRANTS PASS, OREGON 97527

(541) 846-6885

The specific limits for the use are listed below along with conditions of use.

APPLICATION FILE NUMBER: G-13891

SOURCE OF WATER: TWO WELLS IN CARIS CREEK BASIN

PURPOSE OR USE: IRRIGATION OF 4.2 ACRES AND SUPPLEMENTAL IRRIGATION OF 18.7 ACRES

RATE OF ALLOWED USE: 0.1 CUBIC FOOT PER SECOND, BEING 0.078 CFS FROM WELL #1 AND 0.022 CFS FROM WELL #2

PERIOD OF ALLOWED USE: APRIL 1 THROUGH OCTOBER 31

DATE OF PRIORITY: NOVEMBER 25, 1994

POINT OF DIVERSION LOCATION: WELL #1 - SE 1/4 SE 1/4, SECTION 25, 500 FEET NORTH & 10 FEET WEST, WELL #2 - NE 1/4 NE 1/4, SECTION 36, 270 FEET SOUTH & 340 FEET WEST, BOTH FROM NE CORNER, SECTION 36 WITHIN T 37 S, R 5 W, W.M.

The amount of water used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second (or its equivalent) and 2.5 acre-feet for each acre irrigated during the irrigation season of each year.

THE PLACE OF USE IS LOCATED AS FOLLOWS:

	<u>PRIMARY</u>	<u>SUPPLEMENTAL</u>
NW 1/4 SW 1/4	1.2 ACRES	
SW 1/4 SW 1/4		6.0 ACRES
SECTION 30		
NW 1/4 NW 1/4	1.0 ACRE	
SECTION 31		
TOWNSHIP 37 SOUTH, RANGE 4 WEST, W.M.		
SE 1/4 SE 1/4		11.0 ACRES
SECTION 25		
NE 1/4 NE 1/4	2.0 ACRES	1.7 ACRES
SECTION 36		
TOWNSHIP 37 SOUTH, RANGE 5 WEST, W.M.		

Application G-13891

Water Resources Department

PERMIT G12784

Measurement recording and reporting conditions:

- A. The Director may require the permittee to install a meter or other suitable measuring device as approved by the Director. If the Director notifies the permittee to install a meter or other measuring device, the permittee shall install such device within the period stated in the notice. Such installation period shall not be less than 90 days unless special circumstances warrant a shorter installation period. Once installed, the permittee shall maintain the meter or measuring device in good working order and shall allow the watermaster access to the meter or measuring device. The Director may provide an opportunity for the permittee to submit alternative measuring procedures for review and approval.
- B. The Director may require the permittee to keep and maintain a record of the amount (volume) of water used and may require the permittee to report water use on a periodic schedule as established by the Director. In addition, the Director may require the permittee to report general water use information, the periods of water use and the place and nature of use of water under the permit. The Director may provide an opportunity for the permittee to submit alternative reporting procedures for review and approval.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

Use of water under authority of this permit may be regulated if analysis of data available after the permit is issued discloses that the appropriation will measurably reduce the surface water flows necessary to maintain the free-flowing character of a scenic waterway in quantities necessary for recreation, fish and wildlife in effect as of the priority date of the right or as those quantities may be subsequently reduced.

This right is limited to any deficiency in the available supply of any prior right existing for the same land.

STANDARD CONDITIONS

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

