

STATE OF OREGON
COUNTY OF DESCHUTES

PLACED IN U.S. MAIL

NOV - 7 1996

PERMIT TO APPROPRIATE THE PUBLIC WATERS OREGON WATER RESOURCES DEPT

THIS PERMIT IS HEREBY ISSUED TO

HIDDEN VALLEY IMPROVEMENT DISTRICT
PO BOX 243
REDMOND, OREGON 97756

(541)923-7247

The specific limits for the use are listed below along with conditions of use.

APPLICATION FILE NUMBER: G-14221

SOURCE OF WATER: TWO WELLS IN DESCHUTES RIVER BASIN

PURPOSE OR USE: IRRIGATION OF 8.7 ACRES AND GROUP DOMESTIC USE EXPANDED FOR 82 HOUSEHOLDS

MAXIMUM RATE: 0.42 CUBIC FOOT PER SECOND (CFS) BEING, 0.31 CFS FOR GROUP DOMESTIC AND 0.11 CFS FOR IRRIGATION

PERIOD OF USE: YEAR ROUND FOR GROUP DOMESTIC AND MARCH 1 THROUGH OCTOBER 31 FOR IRRIGATION

DATE OF PRIORITY: DECEMBER 8, 1995

POINT OF DIVERSION LOCATION: NE 1/4 SE 1/4, SECTION 6, TOWNSHIP 15 SOUTH, RANGE 13 EAST, W.M.; WELL 1 - 1010 FEET SOUTH AND 630 FEET WEST, WELL 2 - 1050 FEET SOUTH AND 580 FEET WEST, BOTH FROM E 1/4 CORNER SECTION 6

The amount of water used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second (or its equivalent) and 3.0 acre-feet for each acre irrigated during the irrigation season of each year.

THE PLACE OF USE IS LOCATED AS FOLLOWS:

SW 1/4 NE 1/4 GROUP DOMESTIC
SE 1/4 NE 1/4 GROUP DOMESTIC
NE 1/4 SE 1/4 GROUP DOMESTIC 8.7 ACRES
SECTION 6
TOWNSHIP 15 SOUTH, RANGE 13 EAST, W.M.

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a meter or other suitable measuring device as approved by the Director. The permittee shall maintain the meter or measuring device in good working order.
- B. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.
- C. The Director may require the permittee to keep and maintain a record of the amount (volume) of water used and may require the permittee to report water use on a periodic schedule as established by the Director. In addition, the Director may require the permittee to report general water use information, the periods of water use and the place and nature of use of water under the permit. The Director may provide an opportunity for the permittee to submit alternative reporting procedures for review and approval.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

Use of water under authority of this permit may be regulated if analysis of data available after the permit is issued discloses that the appropriation will measurably reduce the surface water flows necessary to maintain the free-flowing character of a scenic waterway in quantities necessary for recreation, fish and wildlife in effect as of the priority date of the right or as those quantities may be subsequently reduced.

To monitor the effect of water use from the well(s) authorized under this permit, the Department requires the water user to make and report annual static water level measurements. The static water level shall be measured in the month of March. Reports shall be submitted to the Department within 30 days of measurement.

Measurements must be made according to the following schedule:

Before Use of Water Takes Place**Initial and Annual Measurements**

The Department requires the permittee to submit an initial water level measurement in the month specified above once well construction is complete and annually thereafter until use of water begins; and

After Use of Water has Begun**Reference Water Level Determination**

Following the first year of water use, the user shall submit one static water level measurement in the month specified above which will establish the reference level against which future annual measurements will be compared. The water user is not required to measure additional water levels after the reference level has been determined unless required by the Director. The additional measurements may be required in a different month. If the measurement requirement is stopped, the Director may restart it at any time.

All measurements shall be made by a certified water rights examiner, registered professional geologist, registered professional engineer, licensed well constructor or pump installer licensed by the Construction Contractors Board and be submitted to the Department on forms provided by the Department. The Department requires the individual performing the measurement to:

- (A) Identify each well with its associated measurement; and
- (B) Measure and report water levels to the nearest tenth of a foot as depth-to-water below ground surface; and
- (C) Specify the method used to obtain each well measurement; and
- (D) Certify the accuracy of all measurements and calculations submitted to the Department.

The water user shall discontinue use of, or reduce the rate or volume of withdrawal from, the well(s) if annual water level measurements reveal any of the following events:

- (A) An average water level decline of three or more feet per year for five consecutive years; or
- (B) A water level decline of 15 feet in fewer than five consecutive years; or
- (C) A water level decline of 25 feet; or
- (D) Hydraulic interference leading to a decline of 25 feet in any neighboring well with senior priority.

The period of non or restricted use shall continue until the annual water level rises above the decline level which triggered the action or until the Department determines, based on the permittee's and/or the Department's data and analysis, that no action is necessary because the aquifer in question can sustain the observed declines without adversely impacting the resource or senior water rights. The water user shall in no instance allow excessive decline, as defined in Commission rules, to occur within the aquifer as a result of use under this permit. If more than one well is involved, the water user may submit an alternative measurement and reporting plan for review and approval by the Department.

