

STATE OF OREGON

COUNTY OF CLACKAMAS

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

SALMON VALLEY WATER COMPANY
PO BOX 205
WELCHES, OREGON 97067

(503)622-4083

The specific limits and conditions of the use are listed below.

APPLICATION FILE NUMBER: G-14271

SOURCE OF WATER: TWO WELLS IN SALMON RIVER BASIN

PURPOSE OR USE: QUASI-MUNICIPAL

MAXIMUM RATE: 0.501 CUBIC FOOT PER SECOND (CFS), BEING 0.334 CFS FROM WELL 1 AND 0.167 CFS FROM WELL 2

PERIOD OF USE: WATER MAY BE APPROPRIATED FROM AUGUST 1 THROUGH AUGUST 31 OF EACH YEAR

DATE OF PRIORITY: MARCH 13, 1996

POINT OF DIVERSION LOCATIONS: SE 1/4 SW 1/4, SECTION 33, T 2 S, R 7 E, W.M.; NE 1/4 NW 1/4, SECTION 4, T 3 S, R 7 E, W.M.: WELL 1 - 55 FEET NORTH AND 50 FEET WEST; WELL 2 - 10 FEET SOUTH AND 50 FEET WEST, BOTH FROM N1/4 CORNER, SECTION 4.

THE PLACE OF USE IS LOCATED AS FOLLOWS: SECTIONS 32 AND 33, TOWNSHIP 2 SOUTH, RANGE 7 EAST, W.M.; SECTIONS 4, 5 AND 9, TOWNSHIP 3 SOUTH, RANGE 7 EAST, W.M.

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a meter or other suitable measuring device as approved by the Director. The permittee shall maintain the meter or measuring device in good working order.
- B. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.
- C. The Director may require the permittee to keep and maintain a record of the amount (volume) of water used and may require the permittee to report water use on a periodic schedule as established by the Director. In addition, the Director may require the permittee to report general water use information,

Application G-14271 Water Resources Department

PERMIT G-13176

the periods of water use and the place and nature of use of water under the permit. The Director may provide an opportunity for the permittee to submit alternative reporting procedures for review and approval.

The use may be restricted if the quality of the source stream, namely the Sandy River, decreases to the point that it no longer meets state and federal water quality standards due to reduced flows.

Use of water under authority of this permit may be regulated if analysis of data available after the permit is issued discloses that the appropriation will measurably reduce the surface water flows necessary to maintain the free-flowing character of a scenic waterway in quantities necessary for recreation, fish and wildlife in effect as of the priority date of the right or as those quantities may be subsequently reduced.

(1) Use of water from the well, as allowed herein, shall be regulated if the well displays:

(a) An average water level decline of three or more feet per year for five consecutive years; or

(b) A total water level decline of fifteen or more feet; or

(c) A hydraulic interference decline of fifteen or more feet in any neighboring well providing water for senior exempt uses or wells covered by prior rights.

(2) The permittee/appropriator shall install a meter or other measuring device suitable to the Director, and shall keep a complete record of water uses.

(3) The permittee/appropriator shall be responsible for complying with each of the following requirements for measuring water levels in the well.

(a) Use of water from a new well shall not begin until the initial water level in the well has been measured. A measurement of initial water level shall be made at the time a pump is installed, but before pumping begins.

(b) In addition to the measurement required in subsection (a) of this section, a water level measurement shall be made each year at the time of spring high water during the period March 15 through April 15.

(c) All water level measurements shall be made by a qualified individual. Qualified individuals include certified water rights examiners, licensed water well drillers, registered geologists, registered professional engineers, registered land surveyors, licensed well constructor, pump installer licensed by the Construction Contractors Board, or the permittee/appropriator.

(d) Any qualified individual measuring a well shall use standard methods of procedure and equipment designed for the purpose of well measurement. The equipment used shall be well suited to the conditions of construction at the well. A list of standard methods of procedure and suitable equipment shall be available from the Department.

(e) The permittee/appropriator shall submit a record of the measurement to the Department on a form available from the Department. The record of measurement shall include both measurements and calculations, shall include a certification as to their accuracy signed by the individual making the measurements, and shall be received not later than 30 days from the date of measurement. The Department shall determine when any of the declines cited in section (1) are evidenced by the well measurement required in section (3).

Within ONE YEAR of permit issuance, the permittee shall submit a water management and conservation plan consistent with OAR Chapter 690, Division 86.

STANDARD CONDITIONS

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

This permit is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.


By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

The Director finds that the proposed use(s) of water described by this permit, as conditioned, will not impair or be detrimental to the public interest.

Actual construction of the well shall begin within one year from permit issuance. Complete application of water to the use shall be made on or before October 1, 2001.

Issued July 22, 1997


Martha O. Pagel, Director
Water Resources Department

Application G-14271 Water Resources Department
Basin 03 Volume 2, Sandy River (Also Misc)
CSL MGMT.CODES 7GR, 7GG, 7JG, 7JR

PERMIT G-13176
District 01