

STATE OF OREGON

COUNTY OF LAKE

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

LAKEVIEW SUBURBAN DOMESTIC WATER SUPPLY DISTRICT
P.O. Box 1262
LAKEVIEW, OREGON 97630

The specific limits for the use are listed below along with conditions of use.

APPLICATION FILE NUMBER: G-14241

SOURCE OF WATER: A WELL IN THOMAS CREEK BASIN WITHIN THE GOOSE & SUMMER LAKES BASIN

PURPOSE OR USE: QUASI-MUNICIPAL

MAXIMUM RATE: 0.89 CUBIC FOOT PER SECOND (400 GALLONS PER MINUTE)

PERIOD OF USE: YEAR ROUND

DATE OF PRIORITY: JANUARY 21, 1996

POINT OF DIVERSION LOCATION: SW 1/4 SE 1/4, SECTION 32, T38S, R20E, W.M.; 50 FEET NORTH & 1348 FEET WEST FROM SE CORNER, SECTION 32

THE PLACE OF USE IS LOCATED AS FOLLOWS:

SW 1/4 SW 1/4
SE 1/4 SW 1/4
SW 1/4 SE 1/4
SE 1/4 SE 1/4

SECTION 33

TOWNSHIP 38 SOUTH, RANGE 20 EAST, W.M.

NE 1/4
NW 1/4
SW 1/4
NW 1/4 SE 1/4
SW 1/4 SE 1/4

SECTION 4

TOWNSHIP 39 SOUTH, RANGE 20 EAST, W.M.

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a meter or other suitable measuring device as approved by the Director. The permittee shall maintain the meter or measuring device in good working order, shall keep

a complete record of the amount of water used each month and shall submit a report which includes the recorded water use measurements to the Department annually or more frequently as may be required by the Director. Further, the Director may require the permittee to report general water use information, including the place and nature of use of water under the permit.

- B. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.

The well shall be cased and sealed into a confining layer at a minimum of 200 feet below land surface.

The water user shall develop a plan to monitor and report the impact of water use under this permit on water levels within the aquifer that provides water to the permitted well. The plan shall be submitted to the Department within one year of the date the permit is issued and shall be subject to the approval of the Department. At a minimum, the plan shall include a program to periodically measure static water levels within the permitted well and the static water levels in a nearby domestic use well identified by the Department of Water Resources as Water Well Report Lake 2059 in the name of Norris and Mary Christensen and located in the SE 1/4 NW 1/4, Section 33, Township 38 South, Range 20 East, W.M.. The plan shall also stipulate a reference water level against which any water-level declines will be compared. If the well listed on this permit or the well identified by the Department of Water Resources as Lake 2059 displays a total static water-level decline of 25 or more feet over any period of years, as compared to the reference level, then the water user shall discontinue use of, or reduce the rate or volume of withdrawal from, the permitted well. Such action shall be taken until the water level recovers to above the 25-foot decline level or until the Department determines, based on the water user's and/or the Department's data and analysis, that no action is necessary because the aquifer in question can sustain the observed declines without adversely impacting the resource or senior water rights. The water user shall in no instance allow excessive decline, as defined in Commission rules, to occur within the aquifer as a result of use under this permit.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

STANDARD CONDITIONS

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

This permit is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

The Director finds that the proposed use(s) of water described by this permit, as conditioned, will not impair or be detrimental to the public interest.

Actual construction of the well shall begin within one year from permit issuance. Complete application of the water to the use shall be made on or before October 1, 2001.

Issued November 12, 1997


Water Resources Department
Director

Basin 13

Volume I Thomas Creek & Misc
MGMT.CODE 7AG, 7AR, 7BG, 7BR

District 12

Application G-14241

Water Resources Department

PERMIT G-13262