

STATE OF OREGON

COUNTY OF LAKE

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

JACK SPARROWK  
P.O. BOX 657  
CLEMENTS, CALIFORNIA 95227

**This superseding permit is issued to describe an amendment for a change in point of appropriation and an additional point of appropriation proposed under Permit Amendment Application T-11817 and approved by Special Order Vol. 93, Page 453, entered Sept. 17 2014, and to describe an extension of time for complete application of water approved May 9, 2014, and partial assignment to a new permittee approved July 5, 2002, and August 12, 2014. This permit supersedes Permit G-11880.**

to use the waters of WELLS 1, 2 and 3 in the DREWS CREEK BASIN for IRRIGATION OF 134.22 ACRES AND SUPPLEMENTAL IRRIGATION OF 507.74 ACRES.

This permit is issued approving Application G-13313. The date of priority is MARCH 5, 1993. The use is limited to not more than 8.025 CUBIC FEET PER SECOND (CFS); 1.56 CFS FOR PRIMARY IRRIGATION AND 2.649 CFS FOR SUPPLEMENTAL IRRIGATION FROM WELL 1, BEING 0.118 CFS FOR PRIMARY AND 3.698 CFS FOR SUPPLEMENTAL IRRIGATION FROM WELL 2, or its equivalent in case of rotation, measured at the wells.

The wells are located as follows:

Twp	Rng	Mer	Sec	Q-Q	Measured Distances
38 S	17 E	WM	16	SE SW	WELL 1: 1257 FEET NORTH AND 3524 FEET WEST FROM THE SE CORNER OF SECTION 16
38 S	17 E	WM	17	SE SE	WELL 2: 480 FEET NORTH AND 45 FEET WEST FROM THE SE CORNER OF SECTION 17
38 S	17 E	WM	16	SW SW	WELL 5: 260 FEET NORTH AND 1170 FEET EAST FROM THE SW CORNER OF SECTION 16

The amount of water used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second (or its equivalent) and 3.0 acre-feet for each acre irrigated during the irrigation season of each year. The use of water during this period shall be limited to April 1 through September 30 of each year.

This right is limited to any deficiency in the available supply of any prior right existing for the same land.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the proposed place of use under this permit is as follows:

WELLS 1 & 5 IRRIGATION					
Twp	Rng	Mer	Sec	Q-Q	Acres
38 S	17 E	WM	20	NE NE	9.13
38 S	17 E	WM	20	SE NE	22.00
38 S	17 E	WM	20	NE SE	12.72
38 S	17 E	WM	21	SW NW	10.18
38 S	17 E	WM	21	NW SW	31.59
38 S	17 E	WM	21	SW SW	39.20
38 S	17 E	WM	21	SE SW	0.80

WELLS 1 & 5 SUPPLEMENTAL IRRIGATION					
Twp	Rng	Mer	Sec	Q-Q	Acres
38 S	17 E	WM	17	SW SE	6.37
38 S	17 E	WM	17	SE SE	0.90
38 S	17 E	WM	20	NE NE	18.90
38 S	17 E	WM	20	NW NE	40.00
38 S	17 E	WM	20	SW NE	39.55
38 S	17 E	WM	20	SE NE	18.00
38 S	17 E	WM	20	NE NW	22.32
38 S	17 E	WM	20	SE NW	16.13
38 S	17 E	WM	20	NE SE	18.00
38 S	17 E	WM	20	NW SE	10.23
38 S	17 E	WM	20	SE SE	9.93
38 S	17 E	WM	21	SE SW	10.79

WELLS 2 & 5 IRRIGATION					
Twp	Rng	Mer	Sec	Q-Q	Acres
38 S	17 E	WM	28	SW SE	9.40

WELLS 2 & 5 SUPPLEMENTAL IRRIGATION					
Twp	Rng	Mer	Sec	Q-Q	Acres
38 S	17 E	WM	28	NE NW	23.29
38 S	17 E	WM	28	NW NW	40.00
38 S	17 E	WM	28	SW NW	39.74
38 S	17 E	WM	28	SE NW	32.39
38 S	17 E	WM	28	NE SW	40.00
38 S	17 E	WM	28	NW SW	26.00
38 S	17 E	WM	28	SW SW	9.30
38 S	17 E	WM	28	SE SW	40.00
38 S	17 E	WM	28	NW SE	7.86
38 S	17 E	WM	28	SW SE	18.00
38 S	17 E	WM	29	NE NE	14.75
38 S	17 E	WM	29	SE NE	4.49

Permit Amendment T-11817 Conditions

Prior to using water from any well listed on this permit, the permittee shall ensure that the wells have been assigned an OWRD Well Identification Number (Well ID tag), which shall be permanently attached to the wells. The Well ID shall be used as a reference in any correspondence regarding the wells, including any reports of water use, water level, or pump test data.

**Dedicated Measuring Tube:** Wells with pumps shall be equipped with a minimum 3/4-inch diameter, unobstructed, dedicated measuring tube pursuant to figure 200-5 in OAR 690-200. If a pump has been installed prior to the issuance of this permit, and if static water levels and pumping levels can be measured using an electrical tape, then the installation of the measuring tube can be delayed until such time that water levels cannot be measured or the pump is repaired or replaced.

Proposed point of appropriation POA #2 shall be reconstructed to have at minimum continuous casing and continuous seal from land surface to 137 feet depth to obtain groundwater solely from the predominantly volcanic/basalt unit.

Proposed point of appropriation POA #3 shall be constructed with at minimum continuous casing and continuous seal from land surface through the entire valley-fill sediment into the predominantly volcanic/basalt unit to obtain groundwater solely from the predominantly volcanic/basalt unit.

Water shall be acquired from the same aquifer as the original points of appropriation.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the wells at all times.

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a totalizing flow meter, or, with prior approval of the Director, another suitable measuring device at each point of appropriation (new and existing). The permittee shall maintain the meters or measuring devices in good working order, shall keep a complete record of the amount of water used each month and shall submit a report which includes the recorded water use measurements to the Department annually or more frequently as may be required by the Director. Further, the Director may require the permittee to report general water use information, including the place and nature of use of water under the permit.

- B. The permittee shall allow the Watermaster access to the meters or measuring devices; provided however, where the meters or measuring devices are located within a private structure, the Watermaster shall request access upon reasonable notice.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

Actual construction work began on or before DECEMBER 6, 1995 and shall be completed on or before October 1, 2018. Complete application of the water shall be made on or before October 1, 2018.

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.


This permit is for beneficial use of water without waste. The water user is advised that new regulations may require use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

The Director of the Water Resources Department has found that the proposed use of water described by this permit, as conditioned, will not impair or be detrimental to the public interest.

Issued this date, Sept 17, 2014.



Dwight French, Water Right Services Division Administrator, for  
Director, Oregon Water Resources Department