

STATE OF OREGON

COUNTY OF KLAMATH

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

MALIN IRRIGATION DISTRICT  
PO BOX 355  
MALIN OR 97632

**This permit expires on October 31, 2021, or when the Governor's March 31, 2021 declaration of drought emergency for Klamath County is terminated, whichever comes first.**

**The permittee assumes all liability associated with use of water under the permit in the event claims of injury or claims for compensation are filed.**

**If injury to existing rights or detriment to the public interest is observed, the Department may regulate water use under this permit to mitigate such injury or detriment, or cancel this permit if mitigation is not possible.**

**Use of water is subject to prior water right permits, certificates and scenic waterway flows.**

The specific limits and conditions of the use are listed below.

APPLICATION FILE NUMBER: G-19120

SOURCE OF WATER: WELL 1 (KLAM 53757) IN LOST RIVER BASIN

PURPOSE OR USE: SUPPLEMENTAL IRRIGATION OF 3081.6 ACRES

MAXIMUM RATE: 1.89 CUBIC FEET PER SECOND

PERIOD OF USE: PERMIT ISSUANCE THROUGH OCTOBER 31

DATE OF PRIORITY: APRIL 26, 2021

AUTHORIZED POINT OF APPROPRIATION:

Twp	Rng	Mer	Sec	Q-Q	Measured Distances
41 S	12 E	WM	10	NW NW	42.0317, -121.4084

This right is limited to any deficiency in the available supply of any prior right existing for the same land.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

The amount of groundwater used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second. The amount of groundwater under this right is further limited to 2.5 acre-feet for each acre irrigated during the irrigation season of each year.

**AUTHORIZED PLACE OF USE:**

Twp	Rng	Mer	Sec	Q-Q	Acres
41 S	12 E	WM	3	SE SW	38.30
41 S	12 E	WM	3	SW SE	21.00
41 S	12 E	WM	9	NE NE	2.90
41 S	12 E	WM	9	SE SE	9.90
41 S	12 E	WM	10	NE NE	36.50
41 S	12 E	WM	10	NW NE	34.70
41 S	12 E	WM	10	SW NE	19.70
41 S	12 E	WM	10	SE NE	38.40
41 S	12 E	WM	10	NE NW	38.80
41 S	12 E	WM	10	NW NW	35.70
41 S	12 E	WM	10	SW NW	28.50
41 S	12 E	WM	10	SE NW	33.10
41 S	12 E	WM	10	NE SW	35.10
41 S	12 E	WM	10	NW SW	18.90
41 S	12 E	WM	10	SW SW	23.00
41 S	12 E	WM	10	SE SW	35.00
41 S	12 E	WM	10	NE SE	35.20
41 S	12 E	WM	10	NW SE	36.40
41 S	12 E	WM	10	SW SE	37.10
41 S	12 E	WM	10	SE SE	36.90
41 S	12 E	WM	11	SW NE	33.30
41 S	12 E	WM	11	SE NE	26.30
41 S	12 E	WM	11	NE NW	26.30
41 S	12 E	WM	11	NW NW	37.10
41 S	12 E	WM	11	SW NW	35.10
41 S	12 E	WM	11	SE NW	35.90
41 S	12 E	WM	11	NE SW	36.90
41 S	12 E	WM	11	NW SW	37.90
41 S	12 E	WM	11	SW SW	39.20
41 S	12 E	WM	11	SE SW	37.70
41 S	12 E	WM	11	NE SE	35.80
41 S	12 E	WM	11	NW SE	36.40
41 S	12 E	WM	11	SW SE	36.70
41 S	12 E	WM	11	SE SE	37.30
41 S	12 E	WM	12	SW NE	31.00
41 S	12 E	WM	12	SW NW	37.00
41 S	12 E	WM	12	SE NW	32.40
41 S	12 E	WM	12	NE SW	38.00
41 S	12 E	WM	12	NW SW	37.00
41 S	12 E	WM	12	SW SW	36.50
41 S	12 E	WM	12	SE SW	37.20

Twp	Rng	Mer	Sec	Q-Q	Acres
41 S	12 E	WM	12	NE SE	36.70
41 S	12 E	WM	12	NW SE	35.90
41 S	12 E	WM	12	SW SE	36.10
41 S	12 E	WM	12	SE SE	20.90
41 S	12 E	WM	13	NE NE	17.90
41 S	12 E	WM	13	NW NE	39.40
41 S	12 E	WM	13	SW NE	35.50
41 S	12 E	WM	13	SE NE	11.00
41 S	12 E	WM	13	NE NW	35.60
41 S	12 E	WM	13	NW NW	39.50
41 S	12 E	WM	13	SW NW	35.20
41 S	12 E	WM	13	SE NW	37.00
41 S	12 E	WM	13	NE SW	32.00
41 S	12 E	WM	13	NW SW	34.50
41 S	12 E	WM	13	SW SW	37.10
41 S	12 E	WM	13	SE SW	38.40
41 S	12 E	WM	13	NE SE	24.90
41 S	12 E	WM	13	NW SE	32.60
41 S	12 E	WM	13	SW SE	35.60
41 S	12 E	WM	13	SE SE	35.60
41 S	12 E	WM	14	NE NE	33.50
41 S	12 E	WM	14	NW NE	35.60
41 S	12 E	WM	14	SW NE	38.00
41 S	12 E	WM	14	SE NE	32.60
41 S	12 E	WM	14	NE NW	38.50
41 S	12 E	WM	14	NW NW	39.20
41 S	12 E	WM	14	SW NW	38.40
41 S	12 E	WM	14	SE NW	36.30
41 S	12 E	WM	14	NE SW	34.00
41 S	12 E	WM	14	NW SW	24.10
41 S	12 E	WM	14	NE SE	35.10
41 S	12 E	WM	14	NW SE	31.90
41 S	12 E	WM	14	SW SE	12.40
41 S	12 E	WM	14	SE SE	35.80
41 S	12 E	WM	15	NE NE	35.10
41 S	12 E	WM	15	NW NE	37.30
41 S	12 E	WM	15	SW NE	37.40
41 S	12 E	WM	15	SE NE	30.60
41 S	12 E	WM	15	NE NW	37.80
41 S	12 E	WM	15	SE NW	27.90
41 S	12 E	WM	15	NE SE	8.80

Twp	Rng	Mer	Sec	Q-Q	Acres
41 S	12 E	WM	15	NW SE	1.90
41 S	12 E	WM	23	NE NE	5.50
41 S	12 E	WM	24	NE NE	31.20
41 S	12 E	WM	24	NW NE	38.00
41 S	12 E	WM	24	SW NE	38.10
41 S	12 E	WM	24	SE NE	34.60
41 S	12 E	WM	24	NE NW	38.90
41 S	12 E	WM	24	NW NW	32.80
41 S	12 E	WM	24	SW NW	5.60
41 S	12 E	WM	24	SE NW	33.50

Twp	Rng	Mer	Sec	Q-Q	Acres
41 S	12 E	WM	24	NE SW	4.50
41 S	12 E	WM	24	NE SE	20.90
41 S	12 E	WM	24	NW SE	22.90
41 S	13 E	WM	18	SW SW	6.50
41 S	13 E	WM	19	NW NW	40.70
41 S	13 E	WM	19	SW NW	30.90
41 S	13 E	WM	19	SE NW	18.30
41 S	13 E	WM	19	NE SW	4.60
41 S	13 E	WM	19	NW SW	4.40

### 1. Water Use Measurement, Recording and Reporting Conditions:

- A. Before water use may begin under this permit, the permittee shall install a totalizing flow meter at each point of appropriation. The permittee shall maintain the meter in good working order.
- B. The permittee shall keep a complete record of the amount of water used each month, and shall submit a report which includes the recorded water use measurements to the Department by **December 1, 2021**. Further, the Director may require the permittee to report general water-use information, including the place and nature of use of water under the permit.
- C. The permittee shall allow the watermaster access to the meter; provided however, where any meter is located within a private structure, the watermaster shall request access upon reasonable notice.
- D. The Director may provide an opportunity for the permittee to submit alternative measuring and reporting procedures for review and approval.

### 2. Water-Level Measurement Access Condition:

Prior to use, the well(s) shall be configured to allow strictly clean water (no oil) static water level measurements with an electric-tape. This can include measurement access via an unobstructed vertical discharge pipe that allows the groundwater level to fluctuate freely within the discharge pipe (no valves, etc.). Otherwise, a dedicated measuring tube must be installed prior to use that has a diameter of 3/4 inch (0.75 inch) or greater, and is designed pursuant to Figure 200-5 in OAR 690-200.

### 3. Regulation Condition:

Groundwater pumping under this permit shall discontinue or be reduced if area wells with permanent primary and/or supplemental groundwater rights are being regulated off due to ground water level decline or interference with senior water rights unless the Department determines no action is necessary (pumping under this permit can continue) because the groundwater resource can sustain continued groundwater pumping under this permit without causing substantial interference with senior water rights.

