

STATE OF OREGON

COUNTY OF MULTNOMAH

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

PORT OF PORTLAND
PO BOX 3529
PORTLAND OR 97208

The specific limits and conditions of the use are listed below.

APPLICATION FILE NUMBER: G-18798

SOURCE OF WATER:

EXTRACTION WELLS: WELL EW-1, WELL EW-2, AND WELL EW-3 IN COLUMBIA RIVER BASIN

INJECTION WELLS: WELL IW-1, WELL IW-2, WELL IW-3, WELL IW-4, WELL IW-5, WELL IW-6, WELL IW-7, AND WELL IW-8 IN COLUMBIA RIVER BASIN

PURPOSE OR USE: INDUSTRIAL USE

MAXIMUM RATE: 10.03 CUBIC FEET PER SECOND

PERIOD OF USE: JANUARY 1 THROUGH DECEMBER 31

DATE OF PRIORITY: MARCH 5, 2019

AUTHORIZED POINTS OF APPROPRIATION:

EXTRACTION WELLS							
POA	POA Name	Twp	Rng	Mer	Sec	Q-Q	Measured Distances
1	EW 1	1 N	2 E	WM	8	SW NE	1730 FEET SOUTH AND 3110 FEET EAST FROM NW CORNER, SECTION 8
2	EW 2	1 N	2 E	WM	8	SW NE	1880 FEET SOUTH AND 3385 FEET EAST FROM NW CORNER, SECTION 8
3	EW 3	1 N	2 E	WM	8	SW NE	2480 FEET SOUTH AND 3455 FEET EAST FROM NW CORNER, SECTION 8

INJECTION WELLS							
POA	POA Name	Twp	Rng	Mer	Sec	Q-Q	Measured Distances
4	IW 1	1 N	2 E	WM	9	NW SW	2360 FEET NORTH AND 100 FEET EAST FROM SW CORNER, SECTION 9
5	IW 2	1 N	2 E	WM	9	NW SW	2195 FEET NORTH AND 490 FEET EAST FROM SW CORNER, SECTION 9
6	IW 3	1 N	2 E	WM	9	NW SW	2450 FEET NORTH AND 590 FEET EAST FROM SW CORNER, SECTION 9
7	IW 4	1 N	2 E	WM	9	NW SW	2680 FEET NORTH AND 705 FEET EAST FROM SW CORNER, SECTION 9
8	IW 5	1 N	2 E	WM	9	NE SW	2130 FEET NORTH AND 1470 FEET EAST FROM SW CORNER, SECTION 9
9	IW 6	1 N	2 E	WM	9	NE SW	1765 FEET NORTH AND 1350 FEET EAST FROM SW CORNER, SECTION 9
10	IW 7	1 N	2 E	WM	9	NE SW	1960 FEET NORTH AND 1425 FEET EAST FROM SW CORNER, SECTION 9
11	IW 8	1 N	2 E	WM	9	NE SW	1623 FEET NORTH AND 1485 FEET EAST FROM SW CORNER, SECTION 9

AUTHORIZED PLACE OF USE:

Twp	Rng	Mer	Sec	Q-Q
1 N	2 E	WM	7	NE NE
1 N	2 E	WM	8	NE NW
1 N	2 E	WM	8	NW NW
1 N	2 E	WM	8	SW NW
1 N	2 E	WM	8	SE NW

1. Water Use Measurement, Recording, and Reporting Condition:

- A. Before water use may begin under this permit, the permittee shall install a totalizing flow meter at each point of appropriation and injection. The permittee shall maintain the device in good working order.
- B. The permittee shall allow the watermaster access to the device; provided however, where any device is located within a private structure, the watermaster shall request access upon reasonable notice.
- C. The permittee shall keep a complete record of the volume of water used and injected each month, and shall submit an annual report which includes the recorded water-use and injection measurements to the Department annually, or more frequently as may be required by the Director. Further, the Director may require the permittee to report general water-use information, including the place and nature of use of water under the permit.
- D. The Director may provide an opportunity for the permittee to submit alternative measuring and reporting procedures for review and approval.

2. Prior to use of water under this permit, the permit holder must register the injection activity with the Oregon Department of Environmental Quality's Underground Injection Control Program, which can be contacted at 2020 SW 4th Ave, Ste 400, Portland OR 97201, or 503-229-5263.

3. All water produced under this permit, with the exception of water discharged solely for back-flushing of injection wells, is to be injected into the three authorized injection wells WELL EW-1, WELL EW-2, AND WELL EW-3. Prior to operation of the system, the permit holder is to submit documentation affirming that any applicable additional requirements of the Department's Division 230 rules have been met, including submission and approval of an injection plan.
4. Groundwater production shall be only from the Troutdale Sandstone Aquifer groundwater reservoir between 400 feet and 500 feet below land surface.
5. **Well Identification Tag Condition:**

Prior to using water from any well listed on this permit, the permittee shall ensure that the well has been assigned an OWRD Well Identification Number (Well ID tag), which shall be permanently attached to the well. The Well ID shall be used as a reference in any correspondence regarding the well, including any reports of water use, water level, or pump test data.


STANDARD CONDITIONS

1. Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.
2. If the number, location, source, or construction of any well deviates from that proposed in the permit application or required by permit conditions, this permit may be subject to cancellation, unless the Department authorizes the change in writing.
3. If substantial interference with surface water or a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.
4. The well(s) shall be constructed and maintained in accordance with the General Standards for the Construction and Maintenance of Water Supply Wells in Oregon. The works shall be equipped with a usable access port adequate to determine water-level elevation in the well at all times.
5. Where two or more water users agree among themselves as to the manner of rotation in the use of water and such agreement is placed in writing and filed by such water users with the watermaster, and such rotation system does not infringe upon such prior rights of any water user not a party to such rotation plan, the watermaster shall distribute the water according to such agreement.
6. Prior to receiving a certificate of water right, the permit holder shall submit to the Water Resources Department the results of a pump test meeting the Department's standards for each point of appropriation (well), unless an exemption has been obtained in writing under OAR 690-217. The Director may require water-level or pump-test data every ten years thereafter.

7. This permit is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.
8. By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.
9. Construction of the well shall begin April 23, 2026. The deadline to begin construction may not be extended. This permit is subject to cancellation proceedings if the construction deadline to begin is missed.
10. Complete application of the water shall be made by April 23, 2026. If beneficial use of permitted water has not been made before this date, the permittee may submit an application for extension of time, which may be approved based upon the merit of the application.
11. Within one year after complete application of water to the proposed use, the permittee shall submit a claim of beneficial use, which includes a map and report, prepared by a Certified Water Rights Examiner.

This Permit supersedes Permit G-18555 which is of no further force or effect.

Issued **JUN 18 2021**



Dwight French
Water Right Services Division Administrator, for
Thomas M. Byler, Director
Oregon Water Resources Department