

Permit No. G- G 3000
APPLICATION FOR A PERMIT

To Appropriate the Ground Waters of the State of Oregon

I, ELLINGSON TIMBER CO., PLYWOOD DIVISION
(Name of applicant)
of P. O. Box 744 Baker, county of Baker,
(Postoffice Address)
state of Oregon, do hereby make application for a permit to appropriate the
following described ground waters of the state of Oregon, **SUBJECT TO EXISTING RIGHTS:**

If the applicant is a corporation, give date and place of incorporation

January 4, 1960 Klamath Falls, Oregon

1. Give name of nearest stream to which the well, tunnel or other source of water development is
situated Powder River
(Name of stream)

tributary of Snake

2. The amount of water which the applicant intends to apply to beneficial use is _____ cubic
feet per second or 1200 gallons per minute.

3. The use to which the water is to be applied is Log deck sprinkling, steam boiler,
wetting down log yard ground dust, misc. plywood plant use, & fire
protection standby. See Remarks:

4. The well or other source is located 846 ft. S. and 163 ft. W. from the E. $\frac{1}{4}$
(N. or S.) (E. or W.)
corner of SECTION 20, T. 9 S., R. 40 E., W. M.
(Section or subdivision)

(If preferable, give distance and bearing to section corner)

(If there is more than one well, each must be described. Use separate sheet if necessary)

being within the NE $\frac{1}{4}$ OF THE SE $\frac{1}{4}$ of Sec. 20, Twp. 9 S., R. 40 E.,
W. M., in the county of BAKER.

5. The NONE to be _____ miles
(Canal or pipe line)
in length, terminating in the _____ of Sec. _____, Twp. _____,
(Smallest legal subdivision)

R. _____, W. M., the proposed location being shown throughout on the accompanying map.

6. The name of the well or other works is Ellingson Plywood Plant Well

DESCRIPTION OF WORKS

7. If the flow to be utilized is artesian, the works to be used for the control and conservation of the
supply when not in use must be described.

NON-ARTESIAN.

8. The development will consist of One Well having a
(Give number of wells, tunnels, etc.)
diameter of 12" inches and an estimated depth of 650 feet. It is estimated that 650
feet of the well will require 10" steel casing. Depth to water table is estimated 8'
(Kind) (Feet)

13. To supply the city of None

in county, having a present population of

and an estimated population of in 19.....

ANSWER QUESTIONS 14, 15, 16, 17 AND 18 IN ALL CASES

14. Estimated cost of proposed works, \$ 15,000.00

15. Construction work will begin on or before Sept. 15, 1965

16. Construction work will be completed on or before Nov. 5, 1965

17. The water will be completely applied to the proposed use on or before Est. June 1, 1966

18. If the ground water supply is supplemental to an existing water supply, identify any application for permit, permit, certificate or adjudicated right to appropriate water, made or held by the applicant. None

ELLINGSON TIMBER CO., PLYWOOD DIVISION

BY: (Signature)
(Signature of applicant)

Remarks: Supplementary description on Item #3

A- Quantities of water to be used are predicted to be:

(1) Log deck sprinkling, 800 gal per min., (2) Steam Boiler, 150 gal. per min., (3) Sprinkling log yard ground dust, 200 gal. per min., (4) Plywood Plant use, 50 gal. per min., (5) Fire protection standby-ordinarily none, however in case of fire the other uses would be cut off and the entire 1200 gal. per min. would be used if needed.

B- HOW THE WATER IS TO BE USED: (1) Log deck sprinkling-

through rain bird sprinklers, (2) Steam boiler-through heat transfer units and the hot water sprayed into steam vats, (3) Log yard ground dust - through fire hoses, (4) Plywood plant use - through plumbing, (5) Fire protection standby - through fire hoses and building sprinkling system.

STATE OF OREGON, }
County of Marion, } ss.

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for completion

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before May 2, 1966

WITNESS my hand this 1st day of March, 1966

RECEIVED
APR 7 1966
STATE ENGINEER
SALLM OREGON

CHRIS L. WHEELER
STATE ENGINEER
By (Signature)
Larry W. Jebousek, ASSISTANT

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 2.67 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is use in plywood plant and log deck sprinkling, being 0.89 c.f.s. for plant use and 1.78 c.f.s. for log deck sprinkling

If for irrigation, this appropriation shall be limited to - - - - - of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be cased as necessary in accordance with good practice and if the flow is artesian the works shall include proper capping and control valve to prevent the waste of ground water.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is February 8, 1966

Actual construction work shall begin on or before April 13, 1967 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1968

Complete application of the water to the proposed use shall be made on or before October 1, 1969

WITNESS my hand this 13th day of April, 1966

Chris I. Wheeler

STATE ENGINEER

Application No. G-3374
Permit No. G-3009

PERMIT

TO APPROPRIATE THE GROUND WATERS OF THE STATE OF OREGON

This instrument was first received in the office of the State Engineer at Salem, Oregon, on the 8th day of February, 1966, at 1:00 o'clock P. M.

Returned to applicant:

Approved:

April 13, 1966

Recorded in book No. of Ground Water Permits on page G 3009

CHRIS I. WHEELER
STATE ENGINEER

Drainage Basin No. 9 page 45

P.C.