

Application No. G-80.95

Permit No. G 7482

RECEIVED

MAY - 5 1977

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

WATER RESOURCES DEPARTMENT
SALEM, OREGON

RECEIVED

MAY 13 1977

WATER RESOURCES DEPT
SALEM, OREGON

I, Jerry Roshak
(Name of Applicant)

of Route 4 Box 392 Sherwood
(Mailing Address) (City)

State of Oregon, 97140 Phone No. 639-1525 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of One
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 6" and an estimated depth of 305 feet.

2. The well or other source is to be located 600 ft. North and 1570 ft. W
(N. or S.) (E. or W.)

from the South East corner of Sec. 34
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the South West $\frac{1}{4}$ of the South East $\frac{1}{4}$ of
Sec. 34 Tp. 2S R. 1W, W. M., in the county of Washington.

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
2S	1W	34	SW $\frac{1}{4}$ SE $\frac{1}{4}$	7.94

4. It is estimated that 140 feet of the well will require Steel casing.
(Kind)

5. Depth to water table is estimated 70 feet. Well drilled by Ray Borches

6. The amount of water which the applicant intends to apply to beneficial use is cubic feet per second or 30 gallons per minute.

7. The use to which the water is to be applied is Irrigation

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.
No

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.
No.

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

The pump is a 3 HP. Goulds. Irrigation system consists of 3" Aluminum pipe for main line . 2" aluminum pipe for latteral..Pipe is in forty foot length
Pump is 220 volt single phase submersible.

11. Construction work will begin on or before..... Completed

12. Construction work will be completed on or before..... Completed

13. The water will be completely applied to the proposed use on or before..... Completed

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G-8095

Permit No. G 7482

C 3188

RECEIVED
MAY - 5 1977
WATER RESOURCES DEPT
SUB-OREGON
SALEM

Permit to appropriate the Public Waters of the State of Oregon

I am hereby to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO NO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.07 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 1/2 acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is May 5, 1977

Actual construction work shall begin on or before September 14, 1978 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1978

Complete application of the water to the proposed use shall be made on or before October 1, 1979

WITNESS my hand this 14th day of September, 1977

James E. Saxon
Water Resources Director