

Application No. G-8130

Permit No. G 7503

RECEIVED
MAY 16 1977
WATER RESOURCES DEPT.
SALEM, OREGON

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

I, Town of Lakeview (Name of Applicant)

of City Hall (Mailing Address), Lakeview (City)

State of Oregon, 97630 (Zip Code) Phone No. 947-2504 do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 1 well (Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 12" and an estimated depth of 360 feet.

2. The well or other source is to be located 530 ft. S (N. or S.) and 140 ft. E (E. or W.)

from the N.W. corner of Section 16 T39S R20E W.M. (Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the N.W. 1/4 of the N.W. 1/4 of

Sec. 16 Tp. 39S R. 20E W.M., W. M., in the county of Lake

3. Location of area to be irrigated, or place of use if use other than irrigation.

DESCRIPTION OF LAND TO BE IRRIGATED OR PLACE OF USE

Twp.	Range	Sec.	NE 1/4				NW 1/4				SW 1/4				SE 1/4			
			NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4	NE 1/4	NW 1/4	SW 1/4	SE 1/4
39S	20E	7															X	X
"	"	10									X	X	X	X			X	
"	"	15	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
"	"	16	X	X	X	X	X											
"	"	22		X	X		X	X		X								

4. It is estimated that 300 feet of the well will require Steel casing. (Kind)

5. Depth to water table is estimated 15 feet. Well drilled by Jack Stooksberry

6. The amount of water which the applicant intends to apply to beneficial use is cubic feet per second or 700..... gallons per minute.

7. The use to which the water is to be applied is Municipal.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Approx. 200' of 10" pipe to tie in to existing system described on permit G 5465, Johnston Model JTA product Lubricated Vertical Turbine pump, 75 H.P. electric

11. Construction work will begin on or before already started

12. Construction work will be completed on or before June 1, 1977

13. The water will be completely applied to the proposed use on or before July 1, 1979

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.


Application No. G-8130

Permit No. G 7503

G 5203

Remarks:

.....
.....
.....
.....
.....
.....


Signature of Applicant
Town Engineer

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before, 19.....

WITNESS my hand this day of, 19.....

Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

16 day of May, 19 77, at 8 o'clock
H M

Application No. G-8130 Permit No. G 7503

G 7503

Application No. G-8130

Permit No. G 7503

CURLS

Permit to Appropriate the Public Waters of the State of Oregon

G 7503

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 1.56 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is May 16, 1977

Actual construction work shall begin on or before September 14, 1978 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1978

Complete application of the water to the proposed use shall be made on or before October 1, 1979

WITNESS my hand this 14th day of September, 19 77

James E. Sisson
Water Resources Director