

Application No. E-8065

Permit No. G 7565  
 ASSIGNED, See Misc. Rec., Vol. 6 p. 763

**STATE OF OREGON WATER RESOURCES DEPARTMENT**

**Application for a Permit to Appropriate Ground Water**

I, Kenneth Moisan (Name of Applicant)  
 of 9155 Wheatland Rd (Mailing Address) Salem (City)  
 State of Oregon (Zip Code) 97303 Phone No. .... do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 2 wells (Give number of wells, tile lines, infiltration galleries, etc.)  
 having a diameter of 10" and an estimated depth of 40' feet.  
 2. The well or other source is to be located #1 1280 8.50  
#2 920 ft. N and 190 ft. W  
 (N. or S.) (E. or W.)  
 from the SE corner of Durbin D1C 60  
 (Public Land Survey Corner)

(If there is more than one well, each must be described)  
 being within the #1 NW SE  
#2 NE  $\frac{1}{4}$  of the SE  $\frac{1}{4}$  of  
 Sec. 14 Tp. 6S R. 3W, W. M., in the county of Marian.

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
<u>6S</u>	<u>3W</u>	<u>14</u>	<u>SE <math>\frac{1}{4}</math> NE <math>\frac{1}{4}</math></u>	<u>7.9</u>
			<u>NE <math>\frac{1}{4}</math> SW <math>\frac{1}{4}</math></u>	<u>21.8</u>
			<u>NE <math>\frac{1}{4}</math> SE <math>\frac{1}{4}</math></u>	<u>22.1</u>
			<u>NW <math>\frac{1}{4}</math> SE <math>\frac{1}{4}</math></u>	<u>27.0</u>
				<u>78.8</u>

4. It is estimated that 40 feet of the well will require 10" reg casing.  
 (Kind)

5. Depth to water table is estimated 17 Well drilled by #2 Willomettte Drilling Co.  
 (Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 99 cubic feet per second or ..... gallons per minute.

7. The use to which the water is to be applied is Irrigation

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

15 hp centrifical pump on each well  
Underground & portable mainline  
Sprinkler system

11. Construction work will begin on or before July 27, 1973

12. Construction work will be completed on or before July 30, 1975

13. The water will be completely applied to the proposed use on or before Aug 1979

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G 8065

Permit No. G 7565

G 1202

Remarks:.....

.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....

X. *Benjamin M. ...*  
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this ..... day of....., 19.....

..... Water Resources Director

By .....

**RECEIVED**

NOV 7 1977

WATER RESOURCES DEPT  
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the ..... day of ....., 19....., at ..... o'clock .....M.

Application No. G-8065

Permit No. G 7565

G 1282

Application No. G 8065

Permit No. G 7565

### Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.99 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is irrigation.

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 1/2 acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is November 7, 1977

Actual construction work shall begin on or before December 2, 1978 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1980

WITNESS my hand this 2nd day of December, 19 77

  
Water Resources Director