

Application No. G-8255

Permit No. G 7603

STATE OF OREGON WATER RESOURCES DEPARTMENT

RECEIVED

JUL - 7 1977

Application for a Permit to Appropriate Ground Water

WATER RESOURCES DEPT  
SALEM, OREGON

JAMES O. DART  
I. THOMAS W. McELRATH D.B.A. DESERT TERRACE MOBILE ESTATES  
(Name of Applicant)

of 5063 So. Hwy 97, REDMOND  
(Mailing Address) (City)

State of OREGON, 97756 Phone No. 548-2546 do hereby  
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 2 WELLS  
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 6" and an estimated depth of 400' + 442' feet.

2. The well or other source is to be located # 1 1207 SOUTH 615 E.  
# 2 820 SOUTH 2 W.  
(N. or S.) (E. or W.)

from the NW corner of SECTION 32  
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the # 1 NW N.W.  
# 2 NE N.E.  $\frac{1}{4}$  of the N.E.  $\frac{1}{4}$  of  
Sec. # 2 31 Tp. 15 R. 13 E, W. M., in the county of DESCHUTES

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
15 S	13 E	32	NW $\frac{1}{4}$ OF NW $\frac{1}{4}$	GROUP DOMESTIC
15 S	13 E	31	NE $\frac{1}{4}$ OF NE $\frac{1}{4}$	GROUP DOMESTIC

4. It is estimated that # 1 400 feet of the well will require 6" steel casing.  
# 2 441 # 1 Hurst Well (Kind) Drilling

5. Depth to water table is estimated # 2 386 Well drilled by # 2 Wasserman Drilling  
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ..... cubic feet per second or ..... 32 ..... gallons per minute. #1 12 GPM #2 20 GPM

7. The use to which the water is to be applied is GROUP DOMESTIC - 450 USERS

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N.A.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N.A.

10.

#### DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

WATER SYSTEM HAS 2 - 5 H.P. 3" SUBMERGED PUMPS, EACH HAVING A CAPACITY OF 30 G.P.M. AT 40 PSI. PUMPS ARE CONTROLLED BY PRESSURE REGULATOR SWITCH & PRESSURE TANKS. THERE IS APPX. 2000 FEET OF 4" TRANSITE MAIN SUPPLY LINE.

11. Construction work will begin on or before ALREADY BEGAN

12. Construction work will be completed on or before OCT. 1, 1978

13. The water will be completely applied to the proposed use on or before OCT. 1, 1979

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G-8255

Permit No. G 7603

U 3006

Remarks: WELLS WILL NOT BE USED FOR IRRIGATION

DESERT TERRACE MOBILE ESTATES

*James E. Sexson*  
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for correction

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before December 5, 1977

WITNESS my hand this 3rd day of October, 1977

James E. Sexson Water Resources Director

By *Larry Toll*  
Larry Toll

RECEIVED  
OCT 7 1977  
WATER RESOURCES DEPT  
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the 7th day of July, 1977, at 11:00 o'clock A.M.

Application No. G-8255

Permit No. G 7603

G 2006

Application No. G-8255

Permit No. G 7603

### Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, **SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.07 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from two wells.

The use to which this water is to be applied is domestic use for 450 houses; being 0.03 c.f.s. from well # 1 and 0.04 c.f.s. from well # 2.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is July 7, 1977

Actual construction work shall begin on or before December 2, 1978 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1980

WITNESS my hand this 2nd day of December, 1977

  
Water Resources Director