

Application No. G-8470

Permit No. G 7791

**RECEIVED STATE OF OREGON WATER RESOURCES DEPARTMENT**

SEP 27 1977

**Application for a Permit to Appropriate Ground Water**

WATER RESOURCES DEPT  
SALEM, OREGON

I, Hewlett-Packard Company  
(Name of Applicant)

of 1000 Circle Blvd Corvallis  
(Mailing Address) (City)

State of Oregon, 97330 Phone No. 757-2000 do hereby  
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 3 wells named A, B and C  
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of A=10"; B+C=12" and an estimated depth of A=55'; B=54'; C=55' feet.

2. The well <sup>"B"</sup> or other source is to be located 1781.38 ft S 48°-35'-13" E ft.  
(N or S) (E or W)

from the SW corner of A. Stewart DLC 46  
(Public Land Survey Corner)

Well A is 250' W, 75' S of Well B; Well C is 260' E, 270' S of Well B  
(If there is more than one well, each must be described)

(see enclosed map) wells A+B being within the SE 1/4 of the NW 1/4 of

Sec. 25 Tp. 11S R. 5W, W. M., in the county of Benton

Well C is SW 1/4 of NE 1/4 sec 25 T11S R5W

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List 1/4 1/4 of Section	List use and/or number of acres to be irrigated
11S	5W	25	SE & NW	5.77 acres
11S	5W	25	SW of NE	0.79 acres
11S	5W	25	NE of SW	4.40 acres
11S	5W	25	NW of SE	1.39 acres

4. It is estimated that 10' <sup>each</sup> feet of the well will require slotted, or screen casing, remainder steel or PVC - see enclosed well reports (Kind)

5. Depth to water table is estimated 20' Well drilled by Mutschler Well Drilling  
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ..... cubic feet per second or 265..... gallons per minute.

7. The use to which the water is to be applied is watering lawns and shrubs and trees

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N.A.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N.A.

10.

#### DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Pipes connect well pumps to a common manhole. Man hole discharge pipe leads to north end of Stewart Lake. A separate pump at the south end of Stewart Lake feeds an underground sprinkler system used to water lawns, shrubs, and trees around building. Pipe sizes leading to pond are marked on map. Each well has a 5 hp electric submersible pump.

11. Construction work will begin on or before 1-77

12. Construction work will be completed on or before 12-80

13. The water will be completely applied to the proposed use on or before 12-80

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. N.A.

Application No. G-8470

Permit No. G 7791

E 1101

Remarks:.....

.....  
.....  
.....  
.....  
.....  
.....  
.....  
.....

Hewlett-Packard - *[Signature]*  
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this ..... day of....., 19.....

Water Resources Director

By .....

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

27<sup>TH</sup> day of SEPTEMBER, 19 77, at 11:00 o'clock  
A.M.

Application No. G-8470

Permit No. G 7791

11 1301

Application No. G-8470

Permit No. G 7791

### Permit to Appropriate the Public Waters of the State of Oregon

PC

*This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:*

*The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.15 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from three wells.*

*The use to which this water is to be applied is irrigation.*

*If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 1/2 acre feet per acre for each acre irrigated during the irrigation season of each year;*

*and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.*

*The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.*

*The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.*

*The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.*

*The priority date of this permit is September 27, 1977*

*Actual construction work shall begin on or before February 8, 1979 and shall*


*thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979*

**Extended to Oct. 1 1981**

*Complete application of the water to the proposed use shall be made on or before October 1, 1980*

**Extended to Oct. 1 1981**

*WITNESS my hand this 8th day of February, 1978*

  
Water Resources Director

24