

G 7807

G 7807

Permit No.

G-1415

Application No.

water right. Mill Creek, Crow Creek Dam and several other city wells.

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing

13. The water will be completely applied to the proposed use on or before April 1978

12. Construction work will be completed on or before January 1978

11. Construction work will begin on or before April, 1977

Pump will be a deep well turbine with approximately 350 hp motor.

Addition.

system and to a new proposed 3,000,000 gal. reservoir above the Columbia View

The water from this well will be pumped into the City of The Dalles distribution

system to adequately describe the proposed distribution system. Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation

DESCRIPTION OF WORKS

10.

ground surface at the source of development.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

7. The use to which the water is to be applied is Municipal

per second or 2000 gallons per minute

6. The amount of water which the applicant intends to apply to beneficial use is 4.46 cubic feet

TOWNSHIP	RANGE	SECTION	40's	NUMBER OF ACRES TO BE IRRIGATED
2 N	13 E	28	W $\frac{1}{2}$ NE $\frac{1}{4}$	
			W $\frac{1}{2}$ Sec	
			W $\frac{1}{2}$ SE $\frac{1}{4}$	
		29	ALL	
		30	ALL	
		32	ALL	
		33	W $\frac{1}{2}$ NE $\frac{1}{4}$	
			W $\frac{1}{2}$	
			SE $\frac{1}{4}$	
		34	SW $\frac{1}{4}$ SW $\frac{1}{4}$	
		36	S $\frac{1}{2}$ SW $\frac{1}{4}$	
			SE $\frac{1}{4}$	
2 N	14 E	31	SW $\frac{1}{4}$	
1 N	13 E	1	ALL	
		2	S $\frac{1}{2}$ NE $\frac{1}{4}$	
			S $\frac{1}{2}$ NW $\frac{1}{4}$	
			S $\frac{1}{2}$	
		3	S $\frac{1}{2}$ NE $\frac{1}{4}$	
			NW $\frac{1}{4}$ NW $\frac{1}{4}$	
			S $\frac{1}{2}$	
		4	ALL	
		5	E $\frac{1}{2}$	
		8	N $\frac{1}{2}$	
		9	N $\frac{1}{2}$	
		10	N $\frac{1}{2}$	
		11	N $\frac{1}{2}$	

Application No. 6/4/5 RECEIVED

Permit No. G 7807 NOV 14 1977

WATER RESOURCES DEPT.
SALEM, OREGON

RECEIVED

SEP 15 1977

WATER RESOURCES DEPT
SALEM, OREGON

Remarks: This application supersedes the application submitted in 1959.....

File No. G-1415. This new application is amended to describe the location of
the well and the boundaries of the use of water.....

x *Milton Gordon*
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps
and data, and return the same for amendment.....

In order to retain its priority, this application must be returned to the Water Resources Director with
corrections on or before December 9, 1977.....

WITNESS my hand this 10th day of October, 1977.....

JAMES E. SEXSON Water Resources Director

By *Vesta R. Garner*
Vesta R. Garner

RECEIVED
NOV 14 1977
WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
12 day of September, 1977, at 8:00 o'clock
A.M.

Application No. G-1415

Permit No. G 7807

G 7807

Permit to Appropriate the Public Waters of the State of Oregon

C. 10011

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

*The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed **4.46** cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from **a well**.*

*The use to which this water is to be applied is **municipal**.*

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

*The priority date of this permit is **March 13, 1959***

*Actual construction work shall begin on or before **February 8, 1979** and shall thereafter be prosecuted with reasonable diligence and be completed on or before **October 1, 1979***

Extended to Oct. 1 1980

*Complete application of the water to the proposed use shall be made on or before **October 1, 1980***

Extended to Oct. 1 1980

*WITNESS my hand this **8th** day of **February**, 19**78***

James E. Skyles
Water Resources Director

RHX