

Application No.....

G-8491

Permit No.....

G-7997

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

WATER RESOURCES DEPT.

SHELDON, OREGON

I, Winema Girl Scout Council, Inc.,

(Name of Applicant)

of 2001 North Keeneway Drive, Medford.

(Mailing Address)

(City)

State of Oregon, 97501 Phone No. 503-773-8423 do hereby

(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of one (1) well.

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 6" and an estimated depth of 355 feet.

2. The well or other source is to be located 1,600 ft. N. and 100 ft. N.E. West

(N. or S.) (E. or W.)

from the S.E. corner of Section 15, T. 37 S., R. 5 E., W.M.

(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the N.E. ¼ of the S.E. ¼ of Sec. 15, Tp. 37S., R. 5E., W.M., in the county of Klamath.

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List ¼ ¼ of Section	List use and/or number of acres to be irrigated
37S	5E	15	NE ¼ of SE ¼	Domestic Use
37S	5E	15	SE ¼ of SE ¼	Domestic Use

4. It is estimated that 36 feet of the well will require steel casing.
(Kind)

5. Depth to water table is estimated 308. Well drilled by E. E. Storey & Son.
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ...0.05..... cubic feet per second or21..... gallons per minute.

7. The use to which the water is to be applied is ...Camp...Low...Echo:....showers,...hand wash-ing,...dish...washing,...laundry.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A.....

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

Approximately 50' to well from stream bed; well is approximately 10' higher.

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Well pump is a Berkeley submersible 4 BL35-3, motor is 3 H.P., 110 V., single phase and is set at 340 feet.

11. Construction work will begin on or before.....7/1/77.....

12. Construction work will be completed on or before7/15/77.....

13. The water will be completely applied to the proposed use on or before.....8/14/77.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. Ground water supply will replace existing surface water right...(Certificate Nos.: 34997 and 32709).....

Application No.....

G-8491

Permit No.....

G 7997

U.S. WEA

Remarks: N/A

Donna Lee Gardner, Pres.

Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for information

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before January 16, 1978

WITNESS my hand this 16th day of November, 1977

James E. Sexson

Water Resources Director

By *West Farmer*

REC'D 11 1978
WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED
MAR 14 1978
WATER RESOURCES DEPT.
SALEM, OREGON

RECEIVED
APR 28 1978
WATER RESOURCES DEPT
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

12th day of October, 1977, at 11:00 o'clock

A.M.

Application No. G-8491 Permit No. G-7997

G-3833

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.05 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is use in girl scout camp.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is February 1, 1978

Actual construction work shall begin on or before April 11, 1979 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1980

WITNESS my hand this 11th day of April , 1978


James E. Person
Water Resources Director

24X C