

Application No. G-8809

Permit No. G-8129

exon 20 00
rec 10 00
30 00

STATE OF OREGON WATER RESOURCES DEPARTMENT**Application for a Permit to Appropriate Ground Water**

I, J. H. MESSER

(Name of Applicant)

of 9974 Mt Angel Gervais Rd. NE, Gervais

(Mailing Address)

(City)

State of OREGON, 97026 Phone No. 792-4404 do hereby

(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 1 WELL

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 10' and an estimated depth of 176 feet.

2. The well or other source is to be located 300 ft. S and 1300 ft. E

(N. or S.)

(E. or W.)

from the N^W NW corner of COONSE DLC 56

(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the NE $\frac{1}{4}$ of the SW $\frac{1}{4}$ of Sec. 31 Tp. 5 S. R. 1 W., W.M., in the county of MARION

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
5 S	1 W	31	NE $\frac{1}{4}$ SW $\frac{1}{4}$	8.5 AC.
			SE $\frac{1}{4}$ SW $\frac{1}{4}$	8.3 AC
				16.8

4. It is estimated that 176 feet of the well will require -250 casing.

(Kind)

5. Depth to water table is estimated 15. Well drilled by WILLAMETTE DRILLING Co.

(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ... 0.21 ... cubic feet per second or gallons per minute.

7. The use to which the water is to be applied is IRRIGATION

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

15 hp Submersible Pump

Portable Sprinkler system

11. Construction work will begin on or before Well is drilled

12. Construction work will be completed on or before Completed

13. The water will be completely applied to the proposed use on or before Oct. 1, 1981

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. None - rights on this land under cert. 40035 are being canceled

Application No. G-8809

Permit No. G 8129

G 8129

Remarks: LD IN FILE 45201

x Joseph H Merser

Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

Water Resources Director

By

RECEIVED
MAY 16 1978
WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
16th day of MAY, 1978, at 10:18 o'clock

A.M.

Application No. G-8809

Permit No.

G 8129

PC Application No. G-8809

Permit No. G-8129

Permit to Appropriate the Public Waters of the State of Oregon

U-8129

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.21 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well.....

The use to which this water is to be applied is irrigation.

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 $\frac{1}{2}$ acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is May 16, 1978

Actual construction work shall begin on or before July 5, 1979 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19....79

Complete application of the water to the proposed use shall be made on or before October 1, 19...80

WITNESS my hand this 5th day of July , 19....78


James E. Hyatt
Water Resources Director