

Application No. G-8826

Permit No. G 8173

STATE OF OREGON WATER RESOURCES DEPARTMENT
Application for a Permit to Appropriate Ground Water

I, The J.M. Smucker Co.
(Name of Applicant)

of 1440 Silverton Road, Woodburn
(Mailing Address) (City)

State of Oregon, 97071 Phone No. 503-982-9931
(Zip Code) do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of One Vertical Well
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 10 inch and an estimated depth of 214 feet.

2. The well or other source is to be located 169.12 ft. S and 3526.18 ft. W
(N. or S.) (E. or W.)

from the E 1/4 corner of SEC 17
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the Northeast 1/4 of the Southwest 1/4 of

Sec. 17 Tp. 5 South R. 1 West, W.M., in the county of Marion

3. Location of area to be irrigated, or place of use if use other than irrigation.

| Township | Range | Section | List 1/4 1/4 of Section | List use and/or number of acres to be irrigated |
|----------|--------|---------|-------------------------|---|
| 5 South | 1 West | 17 | N.E. 1/4, S.W. 1/4 | FOOD PROCESSING |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

4. It is estimated that 214 feet of the well will require steel casing.
(Kind)

5. Depth to water table is estimated 40 Well drilled by R.J. Strasser Drilling Co.
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 1.0 cubic feet per second or 450 gallons per minute.

7. The use to which the water is to be applied is Food Processing

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Worthington Model 10L-30-5 Stage Industrial Vertical Turbine Pump complete with five stage heavy duty bowl section, galvanized cone suction strainer, 170 feet of 5" column with 1" steel line shaft arranged for water lubrication of column bearings driven by 30 horsepower, 1250 rpm, 3 phase 60 cycle, 460 volt V.H.S. motor with N.P.R.

Pumping unit discharges into header system attached directly to 6000 gallon steel reservoir.

11. Construction work will begin on or before November 3, 1977

12. Construction work will be completed on or before January 4, 1978

13. The water will be completely applied to the proposed use on or before July 1, 1978

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G-8826

Permit No. G 8173

G 8132

Remarks:.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....

The J. M. Smuckler Company
Signature of Applicant
C. M. ICENOgle

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this..... day of....., 19.....

Water Resources Director

By.....

RECEIVED
MAY 25 1978
WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

25th day of MAY, 1978, at 1:45 o'clock P.M.

Application No. G-8826

Permit No. G 8173

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 1.0 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well.

RECORDED
DATE: 10/25/78
BY: [illegible]

The use to which this water is to be applied is food processing.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is May 25, 1978

Actual construction work shall begin on or before August 16, 1979 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1980

WITNESS my hand this 16th day of August, 19 78


Water Resources Director

P.H.