

"CERTIFICATE NO. 58995"

Application No. G-8506

Permit No. G 8327

RECEIVED STATE OF OREGON WATER RESOURCES DEPARTMENT

WATER RESOURCES DEPT
SALEM, OREGON

WATER RESOURCES DEPT
SALEM, OREGON

Application for a Permit to Appropriate Ground Water
I, City of La Grande, Engineering Department
(Name of Applicant)

of 104 Elm Street La Grande
(Mailing Address) (City)

State of Oregon 97850 Phone No. 503-963-7161 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of One (1) well
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 16 inches and an estimated depth of 455 feet.
By actual survey 71' N. & 670.47' E ans

2. The well or other source is to be located 70 ft North and 676 ft East
(N. or S.) (E. or W.)

from the Southwest corner of Section 9, T.3.S R.38 E., W.M.
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the Southwest $\frac{1}{4}$ of the Southwest $\frac{1}{4}$ of
Sec. 9 Tp. 3 South R. 38 East, W. M., in the county of Union

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
T3S	R38E	5	Entire Section	Municipal
T3S	R38E	8	Entire Section	Municipal
T3S	R38E	6	All except $\frac{1}{2}$ East $\frac{1}{2}$ SW $\frac{1}{4}$	Municipal
T3S	R38E	7	East 1/2 $\frac{3}{4}$	Municipal
T2S	R38E	31	South $\frac{1}{2}$	Municipal
T2S	R38E	32	South $\frac{1}{2}$	Municipal
T3S	R38E	4	West $\frac{1}{2}$	Municipal
T3S	R38E	9	West $\frac{1}{2}$ & SW $\frac{1}{4}$ SE $\frac{1}{4}$	Municipal
T3S	R38E	17	North $\frac{1}{2}$ & N $\frac{1}{2}$ SE $\frac{1}{4}$	Municipal
"	"	15	SW $\frac{1}{4}$ NW $\frac{1}{4}$	"
"	"	16	NE $\frac{1}{4}$ & N $\frac{1}{2}$ NW $\frac{1}{4}$	"

4. It is estimated that 455 feet of the well will require 375 Steel casing.
(Kind)

5. Depth to water table is estimated 23 feet. Well drilled by Moore Drilling, Inc., Moses Lake, Washington

6. The amount of water which the applicant intends to apply to beneficial use is 3.34 cubic feet per second or 1500 gallons per minute.

7. The use to which the water is to be applied is Municipal

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. *DESCRIPTION OF WORKS*

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

13 stage 12-inch bowl, water lubricated vertical turbine peerless pump;
with 250 horsepower U.S. electric motor.

91 feet of 12-inch pipe, then 700 feet± of 16-inch pipe tying into the
existing water distribution system.

11. Construction work will begin on or before 7/28/77

12. Construction work will be completed on or before 8/26/77

13. The water will be completely applied to the proposed use on or before 11/1/77

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right A well in Island City, 2 wells on the Union Pacific Railroad property,
and the Beaver Creek watershed.

Application No. G-8506

Permit No. G 8327

Remarks:

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

Wm A. Hamilton
Signature of Applicant
10/14/77 CITY ENGINEER

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this..... day of....., 19.....

..... Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the 17th day of OCTOBER, 19 77, at 8:00 o'clock A.M.

Application No. G-8506

Permit No. G 8327

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 3.34 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well.

The use to which this water is to be applied is municipal.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is October 27, 1977.

Actual construction work shall begin on or before November 7, 1979 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1980.

Complete application of the water to the proposed use shall be made on or before October 1, 1981.

WITNESS my hand this 7th day of November, 1978.


Water Resources Director