

"CERTIFICATE NO. 62213"

Application No. G-8971

Permit No. G 8453

STATE OF OREGON WATER RESOURCES DEPARTMENT

RECEIVED

Application for a Permit to Appropriate Ground Water

OCT 16 1978

**WATER RESOURCES DEPT.
SALEM, OREGON**

I, City of Burns
(Name of Applicant)

of City Hall, 90 West Washington
(Mailing Address) Burns
(City)

State of Oregon 97710 Phone No. 573-2383 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of one well
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 16 inches and an estimated depth of 353 feet.

2. The well or other source is to be located 2320 ft. S and 2950 ft. W
(N. or S.) (E. or W.)

from the NE corner of Section 13, T23S, R30E, Willamette Meridian
(Public Land Survey Corner)

(If there is more than one well, each must be described)

..... being within the SE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of
Sec. 13 Tp. 23S R. 30E , W. M., in the county of....Harney.....

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
23S	30E	1	S $\frac{1}{2}$	
		12	A11	
		13	A11	
23S	31E	18	A11	
		7	S $\frac{1}{2}$	
		7	NW $\frac{1}{4}$	
		7	S $\frac{1}{2}$, NE $\frac{1}{4}$	
		7	NW $\frac{1}{4}$, NE $\frac{1}{4}$	
		6	SW $\frac{1}{4}$	
		6	SW $\frac{1}{4}$, SE $\frac{1}{4}$	

4. It is estimated that 350 feet of the well will require 16 .. inch casing.
(Kind)

5. Depth to water table is estimated 50 Well drilled by..... Gaines..Construction.....
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 5.57 cubic feet per second or 2500..... gallons per minute.

7. The use to which the water is to be applied is municipal supply.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N/A

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Vertical Turbine Pump: Water lubricated, 150 foot setting.....

1800 rpm, 2500 gpm, 240' TDH, 200 HP

11. Construction work will begin on or before..... April 7, 1977.....

12. Construction work will be completed on or before June 30, 1978.....

13. The water will be completely applied to the proposed use on or before..... Sept. 28, 1978.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.....

N/A

Application No..... G-8971.....

Permit No..... G-8453.....

Remarks: Well No. 5 has been constructed and modifications.....
to the Burns City Water System have been performed.....
under EDA Project No. 07 51 03747.....

Phyllis Marin
Signature of Applicant
City Recorder

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

..... Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
16th day of October , 1978 , at 8:00 o'clock
A.M.

Application No.....

G-8971

Permit No..... G. 8453.....

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 5.57 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well.....

The use to which this water is to be applied is municipal.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is October 16, 1978

Actual construction work shall begin on or before March 2, 1980 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19.80

Complete application of the water to the proposed use shall be made on or before October 1, 19.81

WITNESS my hand this 2nd day of March , 19.79


James E. Seaton
Water Resources Director