

Application No.....

G-9234

Permit No.....

G-8585

20-
11-8-
31-8-

RECEIVED
STATE OF OREGON WATER RESOURCES DEPARTMENT
MAY 7 1979 Application for a Permit to Appropriate Ground Water
WATER RESOURCES DEPT.
SALEM, OREGON

OREGON, GERRY ACKERMAN, S. O.
 (Name of Applicant)of..... RT 4 Box 197A HILLSBORO
 (Mailing Address) (City)State of OREGON, 97123 Phone No. 628-1630 do hereby
 (Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of O.N.E. WELL
 (Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 12 INCHES and an estimated depth of 720 feet.

2. The well or other source is to be located 420 ft. S. and 2680 ft. E.
 (N. or S.) (E. or W.)from the corner of NE 58° 41' E 1951.78' FARM SURVEYOR
 (Public Land Survey Corner)~~OF CHARLES LEWIS DUE~~ NW Corner Section 31 LM Jr
 (If there is more than one well, each must be described)

being within the NE ¼ ¼ of the NW ¼ ¼ of

Sec. 31 Tp. 1S R. 2W, W.M., in the county of WASHINGTON

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List ¼ ¼ of Section	List use and/or number of acres to be irrigated
1S	2W	30	SW ¼ OF SE ¼	.3
1S	2W	30	SE ¼ OF SE ¼	1.0
1S	2W	31	NW ¼ OF NE ¼	10.5
1S	2W	31	NE ¼ OF NE ¼	19.1
1S	2W	31	SE ¼ OF NE ¼	5.1
				36.0 ACRES

4. It is estimated that 270 feet of the well will require STEEL casing.
 (Kind)5. Depth to water table is estimated 25. Well drilled by JAHSEN.
 (Feet)

6. The amount of water which the applicant intends to apply to beneficial use is cubic feet per second or G.P.M. gallons per minute. SEE ~~REMARKS~~ DESCRIPTION OF WORKS

7. The use to which the water is to be applied is I.R.R.I.G.A.T.I.O.N.

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N/A

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

A 50 H.P. SUBMERSIBLE PUMP IN THE WELL PUMPS INTO L.R.M. POND AT ABOUT 600 GPM. A 60 H.P. CENTRIFIGAL PUMP IN L.R.M. POND SUPPLIES WATER TO THE IRRIGATION SPRINKLERS AT THE RATE OF ABOUT 600 GPM. THE SUPPLY LINE CURRENTLY IS 6" PORTABLE ALUMINUM PIPE. MAXIMUM LENGTH OF SUPPLY LINE IS 2900'.

11. Construction work will begin on or before EXISTING WELL - GR 459

12. Construction work will be completed on or before

13. The water will be completely applied to the proposed use on or before SEPT 30, 1980

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G-9234

Permit No. G 8585

Remarks:.....

Oregon Barry Packing Co.
Signature of Applicant
by Lorne P. McCarthy Jr. Partner

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

*7th day of May, 19 79, at 2:51 o'clock
P.M.*

Application No. G-9234

Permit No. G...8585

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.45 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2½ acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is May 7, 1979

Actual construction work shall begin on or before July 13, 1980 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19.... 80

Complete application of the water to the proposed use shall be made on or before October 1, 19.... 81

WITNESS my hand this 13th day of July , 19.... 79


James E. Sexton
Water Resources Director