

Application No.....

G-9296

Permit No.....

G 8613

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED

JUN 28 1979

WATER RESOURCES DEPT

SALEM, OREGON

I, Watseco-Barview Water District

(Name of Applicant)

of..... P.O. Box 295

Rockway

(City)

(Mailing Address)

State of..... Oregon 97136 Phone No..... 503/355-2666..... do hereby

(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of One shallow dune well having 6 casings.....

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 2" and an estimated depth of 18 feet.

2. The well or other source is to be located 25 ft. South and 565 ft. West.....

(E. or W.)

from the E 1/4 corner of Sec. 18 Twp. R10 WMM

(Public Land Survey Corner)

(If there is more than one well, each must be described)

..... being within the N.E. ¼ of the S.E. ¼ of

Sec. 18 Twp. 1 N R. 10 W , W.M., in the county of Tillamook

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List ¼ ¼ of Section	List use and/or number of acres to be irrigated
1 N	10 W	5	S ₂ ¹ SW ₄ ¹	Quasi-Municipal ✓
		7	NE ₄ ¹ NE ₄ ¹	" "
			S ₂ ¹ NE ₄ ¹ SE ₄ ¹	" "
		8	NE ₄ ¹ NW ₄ ¹ W ₄ ¹	" "
		17	W ₂ ¹ NW ₄ ¹ SW ₄ ¹	" "
		18	E ₂ ¹ SE ₄ ¹ NW ₄ ¹ NE ₄ ¹ SW ₄ ¹	" "
		20	NW ₄ ¹ NE ₄ ¹ NE ₄ ¹ NW ₄ ¹	" "

4. It is estimated that 16 feet of the well will require PVC casing.

(Kind)

5. Depth to water table is estimated 4 Well drilled by Water District

(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ... 224 cubic feet per second or ... 200 gallons per minute.

7. The use to which the water is to be applied is Quasi-Municipal

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

Dune well - no drainage ditch in the area.

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Transmission system 10,300 LF 8" Pipe

Distribution system 6,800 LF 8" Pipe

300,000 Gallons Concrete Reservoirs

Well house with 200 gpm pump

Total Dynamic Head 180 feet

Duplex pumps in line centrifugal

Motor 15HP

11. Construction work will begin on or before August 1, 1979

12. Construction work will be completed on or before March 1, 1979

13. The water will be completely applied to the proposed use on or before March 1, 1979

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. None, this is the only source for the water district

Application No..... G-9596

Permit No..... G 8613

8043

Remarks:.....

The well site is on the Barview County Park.

The property is owned by Tillamook County

George Diel

Signature of Applicant

George Diel, President

Watseco-Barview Water District

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

28th day of *June*, 19⁷⁹, at *8:00* o'clock
A.M.

Application No. *G-9296* Permit No. *G-8613*

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 200 gallons per minute measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well.....

The use to which this water is to be applied is..... quasi municipal.

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is..... June 28, 1979

Actual construction work shall begin on or before August 31, 1980 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19..... 80

Complete application of the water to the proposed use shall be made on or before October 1, 19..... 81

WITNESS my hand this 31st day of..... August , 19..... 79