

CERTIFICATE NO. 52666

Application No. G-9364

Permit No....G...8645

~~exhibit 20~~
~~FCC~~ 115~~5~~

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water AUG 13 1979

I, CHARLES A RAID WATER RESOURCES DEPT.
(Name of Applicant) SALEM, OREGON

**WATER RESOURCES DEPT.
SALEM, OREGON**

of..... 15254 NE MARSHALL MT ARKEL
(Name of Applicant) (Mailing Address) (City)

State of O R E G O N Phone No. 845-2533 do hereby
97362 (Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of WELL

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 8 and an estimated depth of 418 feet.

2. The well or other source is to be located 240 ft. 5 and 1400 ft. W

from the NE corner of SECTION 12
(Public Land Survey Corner)

(If there is more than one well, each must be described)

..... being within the NW $\frac{1}{4}$ of the NE $\frac{1}{4}$ of
Sec. 12 Tp. 6 S R. 1 W , W. M., in the county of MARION

3. Location of area to be irrigated, or place of use if use other than irrigation.

4. It is estimated that 283 feet of the well will require 1250 welds/ casing.
(Kind)

5. Depth to water table is estimated 37 (Feet) Well drilled by Charles Stadelman

6. The amount of water which the applicant intends to apply to beneficial use is 0.44 cubic feet per second or 197 gallons per minute.

7. The use to which the water is to be applied is IRRIGATION

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

300 ft from Creek (winter flow) ± 20 ft above Cr.

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

1.5 hp Submersible Pump

5" mainline

3" lateral

11. Construction work will begin on or before.....

12. Construction work will be completed on or before.....

13. The water will be completely applied to the proposed use on or before Complete.

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. Groundwater Registration cert. GR 2957

15. being canceled.

Application No. G-9364

Permit No. G-8645

Remarks:.....

THIS APPLICATION PREPARED BY:

Don Buell

FROM INFORMATION FURNISHED BY
THE APPLICANT.

x Charles A Reid

Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

*15th day of August, 1979, at 1:18 o'clock
P.M.*

Application No. G-9364

Permit No. G 8645

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.44 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 $\frac{1}{2}$ acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.


The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is August 15, 1979

Actual construction work shall begin on or before October 17, 1980 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1981

Complete application of the water to the proposed use shall be made on or before October 1, 1982

WITNESS my hand this 17th day of October , 1979


James C. Seaton
Water Resources Director

BAX