

Application No. G-8752

Permit No. G 8701

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED
APR 19 1978
WATER RESOURCES DEPT
SALEM, OREGON

I, Merwin Padberg (Name of Applicant) of Ione (City)

of 97843 (Mailing Address) State of Oregon Phone No. 422-7276 do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of Two wells (Give number of wells, tile lines, drop galleries, etc.)
#1 16" having a diameter of #2 12" and an estimated depth of 400 feet.

2. The well or other source is to be located 1180 ft. S and 620 ft. W from the NE corner of Sec 35 T 1S R 24E (Public Land Survey Corner)

(If there is more than one well, each must be described)

Both being within the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Sec. 35 Tp. 1S R. 24E, W. M., in the county of Morrow

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	PRIMARY both well	SUPPL. well #2	
1S	24E	22	NE $\frac{1}{4}$ NE $\frac{1}{4}$	28.8		
			SE $\frac{1}{4}$ NE $\frac{1}{4}$	33.0		
			NE $\frac{1}{4}$ SE $\frac{1}{4}$	25.6		
			SE $\frac{1}{4}$ SE $\frac{1}{4}$	35.9		
			NE $\frac{1}{4}$ NW $\frac{1}{4}$	2.0		
			NW $\frac{1}{4}$ NW $\frac{1}{4}$	32.0		
		23	SW $\frac{1}{4}$ NW $\frac{1}{4}$	38.8		
			SE $\frac{1}{4}$ NW $\frac{1}{4}$	3.8		
			NE $\frac{1}{4}$ SW $\frac{1}{4}$	2.8		
			NW $\frac{1}{4}$ SW $\frac{1}{4}$	37.3		
			SW $\frac{1}{4}$ SW $\frac{1}{4}$	40.		
			SE $\frac{1}{4}$ SW $\frac{1}{4}$	16.2		
			26	NW $\frac{1}{4}$ NE $\frac{1}{4}$	1.2	
				SW $\frac{1}{4}$ NE $\frac{1}{4}$	1.3	
				NE $\frac{1}{4}$ NW $\frac{1}{4}$	39.0	
				NW $\frac{1}{4}$ NW $\frac{1}{4}$	37.0	
				SW $\frac{1}{4}$ NW $\frac{1}{4}$	27.0	6.3
				SE $\frac{1}{4}$ NW $\frac{1}{4}$	38.5	
		27	NE $\frac{1}{4}$ SW $\frac{1}{4}$	7.5	29.7	
			NW $\frac{1}{4}$ SW $\frac{1}{4}$	1.6	38.4	
			SW $\frac{1}{4}$ SW $\frac{1}{4}$		21.0	
			SE $\frac{1}{4}$ SW $\frac{1}{4}$		26.7	
			NE $\frac{1}{4}$ SE $\frac{1}{4}$		0.6	
			NW $\frac{1}{4}$ SE $\frac{1}{4}$		33.2	
SW $\frac{1}{4}$ SE $\frac{1}{4}$			32.3			
SE $\frac{1}{4}$ SE $\frac{1}{4}$			0.5			
NE $\frac{1}{4}$ NE $\frac{1}{4}$	35.0					
NW $\frac{1}{4}$ NE $\frac{1}{4}$	7.5					
SW $\frac{1}{4}$ NE $\frac{1}{4}$	5.0		7.6			
SE $\frac{1}{4}$ NE $\frac{1}{4}$	25.8		14.0			
NE $\frac{1}{4}$ SE $\frac{1}{4}$		40.				
NW $\frac{1}{4}$ SE $\frac{1}{4}$		34.4				
SW $\frac{1}{4}$ SE $\frac{1}{4}$		7.6				
SE $\frac{1}{4}$ SE $\frac{1}{4}$		18.8				

4. It is estimated that 20 feet of the well will require Steel casing. (Kind)

5. Depth to water table is estimated _____ Well drilled by _____ (Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 10.42 cubic feet per second or gallons per minute.

7. The use to which the water is to be applied is Irrigation and Supplemental Irrigation.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

6. The amount of water which the applicant intends to apply to beneficial use is cubic feet per second or gallons per minute. *see above*

7. The use to which the water is to be applied is

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

New Well: 125 Hp Pump

Old Well: 300 Hp Pump

200 foot Diameter holding pond

21 500 foot buried steel mainling

1 10 Tower Center Pivot

1 9 Tower Center Pivot

1 8 Tower Center Pivot

11. Construction work will begin on or before.....Completed.....

12. Construction work will be completed on or before.....Completed.....

13. The water will be completely applied to the proposed use on or before.....Completed.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right..... Well # 1 Certificate #42254 Permit #G-6296.....

Application No. G-8752.....

Permit No. G 8701.....

Remarks: Well # 2 will be supplemental to Well # 1, making up any deficiency.

Martin Padua
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for correction and completion

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before December 12, 1979

WITNESS my hand this 12th day of October, 1979

James E. Sexson Water Resources Director

By *Donald R. Buell*

Donald R. Buell

RECEIVED
DEC 10 1979
WATER RESOURCES DEPT
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the 19th day of April, 1978, at 8:00 o'clock A.M.

Application No. G-8752

Permit No. G 8701

Application No. G-8752

Permit No. G 8701

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed10.42..... cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from...2...wells.....

The use to which this water is to be applied is.....irrigation and supplemental irrigation....

If for irrigation, this appropriation shall be limited to1/80th..... of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed ...3.0..... acre feet per acre for each acre irrigated during the irrigation season of each year;

Provided further that the right allowed herein shall be limited to any deficiency in the available supply of any prior right existing for the same land and shall not exceed the limitation allowed herein.


and shall be subject to such reasonable rotation system as may be ordered by the proper state officer. The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times. The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is....April 19, 1978.....

Actual construction work shall begin on or beforeJanuary 9, 1981..... and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1981.....

Complete application of the water to the proposed use shall be made on or before October 1, 1982.....

WITNESS my hand this9th..... day of.....January....., 19 80


Water Resources Director