

"CERTIFICATE NO. 55362"

Application No. G-9379

Permit No. G 8799

RECEIVED

AUG 24 1979

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED

JUL - 9 1979

WATER RESOURCES DEPT
SALEM, OREGON

WATER RESOURCES DEPT
SALEM, OREGON

I, City of Fossil, Oregon
(Name of Applicant)

of P.O. Box 467 Fossil, Oregon 97830
(Mailing Address) (City)

State of Oregon, Phone No. 763-2698 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of one well
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of eight inches and an estimated depth of 440 feet.

2. The well or other source is to be located 510 ft. S and 45 ft. E
(N. or S.) (E. or W.)

from the Northwest corner of Section 4, Township 7 South, Range 21 East, W.M.
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the NW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of
Sec. 4 Tp. 7 South R. 21 East, W.M., in the county of Wheeler

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
6 S	21 E	32 & 33	NWNE, NENE, NWSE NESE, SESE	None
"	"	33	SWNW, SENW, NWSW NESW, SWSW, SESW	

4. It is estimated that 110 feet of the well will require Steel casing.
(Kind)

5. Depth to water table is estimated 50 Well drilled by Blue Mt. Well Drilling
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is cubic feet per second or .350..... gallons per minute.

7. The use to which the water is to be applied is Municipal Water Supply

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

450 feet, well is 70 feet higher than creek

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

.....20000 feet of Ductile Iron to connect to existing City of Fossil system.....

11. Construction work will begin on or before.....June 1, 1978.....

12. Construction work will be completed on or before June 1, 1979.....

13. The water will be completely applied to the proposed use on or before.....June 1, 1979.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.Two existing wells located in the SW¹ of Sec. 33, T. 6 S., R. 21 E., W. 4 N.

Application No.G-9379.....

Permit No.G 8799.....

G 8800

Remarks:.....

.....
.....
.....
.....
.....
.....
.....

City of Fossil David H. Scott Mayo
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for..... completion.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before..... March 28....., 19.80.....

WITNESS my hand this ... 28th..... day of..... January....., 19.80.....

James E. Sexson..... Water Resources Director

By.....
Ralph H. Jackson

RECEIVED
FEB 22 1980
WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the 24th day of August, 19 79, at 8 o'clock A.M.

Application No..... G-9379.....

Permit No..... G 8799.....

Permit to appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 350 gallons per minute ~~only per second~~ measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from..... one well.....

The use to which this water is to be applied is..... municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is August 24, 1979

Actual construction work shall begin on or beforeApril 9, 1981..... and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1981.....

Complete application of the water to the proposed use shall be made on or before October 1, 1982.....

WITNESS my hand this 9th day of April 19 80

Water Resources Director