

56629

CERTIFICATE NO. _____ "

Application No. G-9485.....

Permit No. G 8938.....

STATE OF OREGON WATER RESOURCES DEPARTMENT

RECEIVED

Application for a Permit to Appropriate Ground Water

DEC 10 1979

WATER RESOURCES DEPT
SALEM, OREGON

I, CITY OF WOOD VILLAGE.....

(Name of Applicant)

of..... 2055 N.E. 238th Drive....., Troutdale, Oregon.....
(Mailing Address) (City)State of..... Oregon....., 97060..... Phone No..... 667-6211..... do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of One well.....

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 12-inches..... and an estimated depth of 400 feet..... feet.

2. The well or other source is to be located 1510..... ft.... North..... and 1290..... ft.... West.....
(N. or S.) (E. or W.)from the Southeast..... corner of Section 27.....
(Public Land Survey Corner)

(If there is more than one well, each must be described)

..... being within the Northeast..... ¼ of the Southeast..... ¼ of

Sec. 27..... Tp. 1..... South..... R. 3 East....., W.M., in the county of Multnomah.....

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List ¼ ¼ of Section	List use and/or number of acres to be irrigated	MUNICIPAL service area
1 North	3 East	26	SW 1/4, NW 1/4 NW 1/4, SW 1/4	6 acres 12 acres	
		27	SE 1/4, NE 1/4 SW 1/4, NE 1/4	21 acres 19 acres	
		27	SE 1/4, NW 1/4 NE 1/4, SW 1/4	33 acres 31 acres	
		27	SE 1/4, SW 1/4 SW 1/4, SW 1/4	18 acres 3 acres	
		27	NW 1/4, SE 1/4 NE 1/4, SE 1/4	35 acres 40 acres	
		27	SW 1/4, SE 1/4 SE 1/4, SE 1/4	37 acres 40 acres	
		34	NW 1/4, NW 1/4 NE 1/4, NW 1/4	13 acres 19 acres	
		34	SE 1/4, NW 1/4 NW 1/4, NE 1/4	11 acres 40 acres	
		34	NE 1/4, NE 1/4 SW 1/4, NE 1/4	40 acres 28 acres	
		34	SE 1/4, NE 1/4 NW 1/4, NW 1/4	28 acres 2 acres	
		35	SW 1/4, NW 1/4	3 acres	

4. It is estimated that 300..... feet of the well will require 12-inch..... casing.
(Kind)5. Depth to water table is estimated 100..... Well drilled by..... cable or rotary.....
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is ...1,114..... cubic feet per second or 500 gallons per minute.

7. The use to which the water is to be applied isMUNICIPAL.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N/A

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Deep well turbine pump; 60 hp electric motor; 12-inch pipe line connecting to City's distribution system; flow meter.

11. Construction work will begin on or before.....March 1, 1980.....

12. Construction work will be completed on or before.....September 1, 1980.....

13. The water will be completely applied to the proposed use on or before.....September 1, 1980.....


14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.Well No....1,..Registration No....GR-1589..May 20, 1958.....
.....Certificate No. GR-1537, Recorded Book No. 7
.....Well No....2,..Application No....G-4428..June 3, 1968.....
.....Permit No. G-4172, February 14, 1969

G 8938

Application No. G-9485.....

Permit No.

Remarks.....


Signature of Applicant

Bruce B. Baldt, Mayor - CITY OF WOOD VILLAGE

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for..... correction and completion.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before..... September 29, 1980.....

WITNESS my hand this 28th day of..... July....., 19... 80.....

Water Resources Director

By 
Donald R. Buell

RECEIVED

AUG 4 1980
WATER RESOURCES DEPT
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
10th day of December, 19.... 99....., at 11:00 o'clock

A. M.

Application No. G-9485

Permit No.

G 8938

Application No. G-9485

Permit No.

G-8938

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 1.114 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from a well

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is December 10, 1979

Actual construction work shall begin on or before September 19, 1981 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1981

Extended to Oct. 1, 1986

Complete application of the water to the proposed use shall be made on or before October 1, 1982

Extended to Oct. 1, 1986

WITNESS my hand this 19th day of September , 19...80

Water Resources Director

RHF A

James E. Seaman