

Application No. 10028

Permit No. G 5103

G 9165

STATE OF OREGON WATER RESOURCES DEPARTMENT CENTRE

Application for a Permit to Appropriate Ground Water

NOV 20 1980

WATER RESOURCES DE
SALEM, OREGON

I, Glen Bridgmon (Name of Applicant)

of..... Rt 6, Box 5800 Lakeview
(Mailing Address) (City)

(Mailing Name) (City)

State of Oregon 97630 *Phone No.* 947-4211 *do hereby*

(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 1 (one) well
(Give number of wells, tile lines, infiltration galleries, etc.)

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 18 and an estimated depth of 440 feet.

2. The well or other source is to be located 1300 ft. N. (N. or S.) and 100 ft. E. (E. or W.)

from the S $\frac{1}{2}$ corner of Section 30 Tp. 38S R. 20E (corners not found).
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the SW $\frac{1}{4}$ of the SE $\frac{1}{4}$ of
Sec. 30 *Tp.* 38S *R.* 20E , *W. M., in the county of* Lake

3. Location of area to be irrigated, or place of use if use other than irrigation.

4. It is estimated that \$ 440..... feet of the well will require 400 ft solid
..... casing.

5. Depth to water table is estimated ... 30 ft Well drilled by..... C and C Enloe
(Feet) 1

6. The amount of water which the applicant intends to apply to beneficial use is 1.32 Primary
..... per second or gallons per minute. 4.24 Supplemental cubic feet

7. The use to which the water is to be applied is Irrigation and Supplemental Irrigation

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

40 ft West of Thomas Cr. 10 ft in elevation higher than creek.

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

5130 ft 6" main line

2750 ft 8" main line

3 - 5" 1320 ft wheel lines

1 - 5" 1320 ft wheel line with tag line

1 - 75 HP Turbine well pump

1- 60 HP Booster pump (centrifugal)

11. Construction work will begin on or before Has begun

12. Construction work will be completed on or before Oct. 1, 1981

13. The water will be completely applied to the proposed use on or before Oct. 1 1982

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. Thomas Cr. Trib. Goose Lake, Decree Certificates #'S 5246, 5260, 5254, 5240 and 5228 + Supplemental Appl. 5345, permit 3237 Cert. 1845

Application No.

G - 10028

Permit No.

G 9165

8 1162

SUPPLEMENTAL IRRIGATION

91.B.

DESCRIPTION OF LAND TO BE IRRIGATED OR PLACE OF USE

Remarks:

RECEIVED

NOV 20 1980

WATER RESOURCES DEPT. Application No. G-10028
Permit No. G 9165

Remarks: Applicant intends to pump water from well into the channel of Thomas cr. and recover the ground water at a point 1300 ft South and 180 ft West from the N $\frac{1}{2}$ corner of Section 31 being within the NE $\frac{1}{4}$ NW $\frac{1}{4}$ of Section 31 Tp. 38S R. 20E indicated on the application map as P.O.R.C. for supplemental use in section 31. There is an existing pump station at this point. There are no intervening points of diversion.

Glen Bindgarn
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before....., 19.....

WITNESS my hand this day of , 19.....

Water Resources Director

By

*This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
20 day of November , 19 80 , at 11:00 o'clock*

A.M.

Application No. G- 10028

Permit No. G 9165

G 9165

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 5.56 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from one well

The use to which this water is to be applied is..... irrigation and supplemental irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 3 acre feet per acre for each acre irrigated during the irrigation season of each year; provided further that the right allowed herein shall be limited to any deficiency in the available supply of any prior right existing for the same land and shall not exceed the limitation allowed herein, provided further that the amount of water rediverted from the channel of Thomas Creek shall not exceed the amount by which the flow of Thomas Creek is increased above the natural flow by the operation of the well,.....

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is ..November 20, 1980.....

Actual construction work shall begin on or beforeMarch 3, 1982..... and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19.82.....

Complete application of the water to the proposed use shall be made on or before October 1, 19.83.....

WITNESS my hand this 3rd day of..... March....., 19.81.....

James E. Pearson
Water Resources Director

BH B