

Application No. G-10123

Permit No. G 9201

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED

JAN 26 1981

WATER RESOURCES DEPT
SALEM, OREGON

I, Jeremiah O'Leary
(Name of Applicant)

of Summer Lake Summer Lake
(Mailing Address) (City)

State of Oregon, 97640 Phone No. 943-3961 or 576-2568 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 1 Well
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 14" and an estimated depth of 346 feet.

2. The well or other source is to be located 1320 ft. N and 200 ft. E
(N. or S.) (E. or W.)

from the SW corner of Sec. 27, T28S, R15E
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the SW $\frac{1}{4}$ of the SW $\frac{1}{4}$ of
Sec. 27 Tp. 28S R. 15E, W. M., in the county of Lake

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated.
28S	15E	27	NE $\frac{1}{4}$ SW $\frac{1}{4}$	40.0
			NW $\frac{1}{4}$ SW $\frac{1}{4}$	8.0
			SW $\frac{1}{4}$ SW $\frac{1}{4}$	8.0
			SE $\frac{1}{4}$ SW $\frac{1}{4}$	40.0
			NW $\frac{1}{4}$ SE $\frac{1}{4}$	32.0
			SW $\frac{1}{4}$ SE $\frac{1}{4}$	32.0
				160.0

4. It is estimated that 136 feet of the well will require Steel casing.
(Kind)

5. Depth to water table is estimated 52 Well drilled by Lyle Adams
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 4.5 cubic feet per second or gallons per minute.

7. The use to which the water is to be applied is Irrigation.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

N/A.....

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

N/A.....

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

50 HP Turbine Pump.....

2640' 8" Main Line.....

4 1320' 4" Wheel Lines.....

11. Construction work will begin on or before.....Has begun.....

12. Construction work will be completed on or before.....October 1, 1982.....

13. The water will be completely applied to the proposed use on or before.....October 1, 1983.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.....

Application No. G-10123.....

Permit No. G 9201.....

Remarks: Applicant is applying for a duty of water of 4.5 acre feet
per acre per Irrigation Season

This permit, when issued, is for the beneficial use of water. By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan. It is possible that the land use you propose may not be allowed if it is not in keeping with the goals and the acknowledged plan. Your city or county planning agency can advise you about the land-use plan in your area.

Journal O'Leary
Signature of Applicant

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before, 19

WITNESS my hand this day of, 19

Water Resources Director

By

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

26 day of January, 1981, at 11:00 o'clock
A.M.

Application No. G-10123

Permit No. G 9201

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, **SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 2.0 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from one well

The use to which this water is to be applied is irrigation.

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 3 acre feet per acre for each acre irrigated during the irrigation season of each year;


and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.
The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.
The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.
The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is January 26, 1981

Actual construction work shall begin on or before March 24, 1982 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1982

Complete application of the water to the proposed use shall be made on or before October 1, 1983

WITNESS my hand this 24th day of March, 19 81


Deputy Water Resources Director

RHJ E