

Application No. G-9541

Permit No. G 9321

CERTIFICATE NO. 53555

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED
FEB 11 1980
WATER RESOURCES DEPT
SALEM, OREGON

I, DAVE UMBARGER
(Name of Applicant)

of RT 1, BOX 600
(Mailing Address) PENDLETON
(City)

State of OREGON, 97801 Phone No. 503-276-4664
(Zip Code) do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of ONE WELL
(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 8" and an estimated depth of 325 feet.

2. The well or other source is to be located 1700 ft. S and 1620 ft. W
(N. or S.) (E. or W.)

from the NE corner of SEC 29
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the NW $\frac{1}{4}$ of the NE $\frac{1}{4}$ of

Sec. 29 Tp. 2N R. 33E, W. M., in the county of UHATILLA

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
<u>2N</u>	<u>33E</u>	<u>29</u>	<u>NW NE</u>	<u>40</u>
<u>2N</u>	<u>33E</u>	<u>29</u>	<u>NE NE</u>	<u>20</u>
				<u>60</u>

4. It is estimated that 30 feet of the well will require STANDARD casing.
(Kind)

5. Depth to water table is estimated UNK Well drilled by LARRY BURD WELL DRIVING
(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is 0.75 cubic feet per second or 336 gallons per minute.

7. The use to which the water is to be applied is IRRIGATION

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

- 0 -

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

500' TO NEAREST POINT 30' DIFFERENCE IN ELEVATION

10. **DESCRIPTION OF WORKS**

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

2.5 HP SUBMERSIBLE PUMP, ELECTRIC MOTOR

1320' BURIED 4" PVC PIPE WITH RISERS

990' 3" ALUMINUM PORTABLE PIPE LINE WITH SPRINKLERS

EVERY 40'

11. Construction work will begin on or before FEBRUARY 1, 1980

12. Construction work will be completed on or before FEBRUARY 1, 1981

13. The water will be completely applied to the proposed use on or before FEBRUARY 1, 1982

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.

Application No. G-9541

Permit No. G 9321

8 8884

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, **SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.75 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from one well

The use to which this water is to be applied is irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 3 acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer. The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is February 11, 1980

Actual construction work shall begin on or before June 15, 1982 and shall

thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1982

Extended to Oct. 1, 1983
Complete application of the water to the proposed use shall be made on or before October 1, 1983

WITNESS my hand this 15th day of June, 1981


Water Resources Director

RAY 9