

Application No. G-10268

Permit No. WOLF 1980 317
G 9419

RECEIVED

STATE OF OREGON WATER RESOURCES DEPARTMENT

APR 10 1981

Application for a Permit to Appropriate Ground Water

WATER RESOURCES DEP

SALEM, OREGON

Aldrich Ranches, a partnership consisting of Leonard Aldrich,
I, Eunice Aldrich, Bruce Aldrich and Lavon Aldrich
(Name of Applicant)

of Route 2, Box 2764 Hermiston
(Mailing Address) (City)

State of Oregon, 97838 Phone No. 567-8040 do hereby
(Zip Code)

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of 5 wells
(Give number of wells, tile lines, infiltration galleries, etc.)
having a diameter of 12" - 16" and an estimated depth of 350-400 See EXHIBIT A-1
feet.

2. The well or other source is to be located SEE EXHIBIT A and ft.
(N. or S.) (E. or W.)
from the corner of
(Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the ¼ of the ¼ of
Sec. 26S Tp. 26S R. 30 E., W. M., in the county of Harney

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List ¼ ¼ of Section	List use and/or number of acres to be irrigated
		SEE EXHIBIT B		

4. It is estimated that 300 feet of the well will require See EXHIBIT A-1 steel casing.
(Kind)

5. Depth to water table is estimated 50-100 Well drilled by Larry Burd and Others
(Feet) See EXHIBIT A-1

6. The amount of water which the applicant intends to apply to beneficial use is 31.8 cubic feet per second or 14,271 gallons per minute.

7. The use to which the water is to be applied is irrigation and supplemental irrigation

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

10. DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

The wells will be equipped with 100-150 horse power turbine pumps and electric motors. The water will be delivered to circles and solid set through buried and open pipe the diameter of which will depend on the respective yields of the wells.

See EXHIBIT A-1

11. Construction work will begin on or before has begun

12. Construction work will be completed on or before 2 years from the date of Permit

13. The water will be completely applied to the proposed use on or before 3 years from the date of Permit

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. Vol. 38, Page 46262 (Certificate)

Application No. G 10268

Permit No. G 9419

G 8733

RECEIVED

JUL 29 1981

WATER RESOURCES DEPT
SALEM, OREGON

EXHIBIT A

Well No.

1 1,300 feet S. and 8 feet E.
from the NW corner of SECTION
9 being within the NW
Quarter of the NW Quarter of
Section 9.

2 2,826 feet N. and 1,747 feet W.
from the SE corner of SECTION
9 being within the SW
Quarter of the NE Quarter of
Section 9.

3 1,294 feet N. and 1,376 feet W.
from the SE corner of SECTION
9 being within the SW
Quarter of the SE Quarter of
Section 9.

4 1,200 feet N. and 500 feet E.
from the SW corner of SECTION
10 being within the SW
Quarter of the SW Quarter of
Section 10.

5 2,166 feet S. and 1,850 feet E.
from the NW corner of SECTION
15 being within the SE
Quarter of the NW Quarter of
Section 15.

Application No. 10268
Permit No. G 9419

EXHIBIT A-1

RECEIVED

JUL 29 1981

WATER RESOURCES DEPT
SALEM, OREGONWell No.

1. Diameter: 16 inch
Depth: 400 feet
Amount and type of casing: 16 inch to 18 feet
12 inch to 358 feet
(all steel)
Estimated depth to water table: 70 feet
Driller: Larry Burd Well Drilling, Inc.
Pump and motor: Johnson pump, 150 h.p. Newman motor
2. Diameter: 16 inch
Depth: 275 feet
Amount and type of casing: 16 inch to 20 feet
14 inch to 140 feet
(all steel)
Estimated depth to water table: 70 feet
Driller: Larry Burd Well Drilling, Inc.
Pump and motor: Gould pump and 100 h.p. Newman motor
3. Diameter: 14 inch
Depth: 272 feet
Amount and type of casing: 14 inch to 264 feet
(all steel)
Estimated depth to water table: 70 feet
Driller: Western Water Wells, Inc.
Pump and motor: Gould pump and 125 h.p. Newman motor
4. Diameter: estimated 12 inches
Depth: estimated 300 feet
Amount and type of casing: estimated 200 feet of steel casing
Estimated depth to water table: 90 feet
Driller: Unknown (drilled by previous owner)
Pump and motor: Gould pump and 200 h.p. Newman motor
5. Diameter: estimated 12 inches
Depth: estimated 200 feet
Amount and type of casing: estimated 200 feet steel casing
Estimated depth to water table: estimated 90 feet
Driller: Unknown (drilled by previous owner)
Pump and motor: Gould pump and 100 h.p. Newman motor

Application No. G-10268

1 - Exhibit A-1

Permit No. G 9419

RECEIVED
 JUL 29 1981
 WATER RESOURCES DEPT
 SALEM, OREGON

EXHIBIT B

ACRES TO BE IRRIGATED

TWNShP	RANGE	SECTION	PRIMARY	ACRES
			<u>¼¼ SECTION</u>	
26S	30 E., W.M.	4	SW¼SE¼	40
			SE¼SE¼	40
		5	SE¼SE¼	40
			8	NE¼NE¼
		SE¼NE¼		40
		9	NE¼NE¼	40
			NW¼NE¼	40
			SW¼NE¼	40
			SE¼NE¼	40
			NW¼NW¼	40
			SW¼NW¼	40
			SE¼NW¼	40
			NE¼SW¼	40
			NW¼SW¼	40
			SW¼SW¼	40
			SE¼SW¼	40
			10	SW¼SW¼
		15	NW¼NE¼	40
			SW¼NE¼	40
			SE¼NE¼	40
	NE¼NW¼	40		
	NW¼NW¼	40		
	SW¼NW¼	40		
	SE¼NW¼	40		
	NE¼SW¼	40		
	NW¼SW¼	40		
	NE¼SE¼	40		
	NW¼SE¼	40		

1120

SUPPLEMENTAL

TWNShP	RANGE	SECTION	<u>¼¼ SECTION</u>	ACRES
26S	30 E., W.M.	9	NE¼SE¼	30
			NW¼SE¼	40
			SW¼SE¼	40
			SE¼SE¼	40

Application No. 10268
Permit No. G 9419

1,270

Remarks: The plan is to integrate the 5 wells. Because a water right has already been issued for #4, it will be primary for the land described in Certificate 46262 and supplemental to the remaining land described herein. Wells 1, 2, 3 and 5 will be primary for all of the land except that described in Certificate 46262 and supplemental for that land.

ALDRICH RANCHES

By

Gene Aldrich
Signature of Applicant

a general partner

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for correction and completion

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before August 6, 1981

WITNESS my hand this 5 day of June, 1981

James E. Sexson

Water Resources Director

By

Stephen C. Brown

Stephen C. Brown

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

10 day of April, 1981, at 11:00 o'clock
A.M.

Application No. G 10268

Permit No. G 9419

RECEIVED
-JUL 29 1981
WATER RESOURCES DEPT.
SALEM, OREGON

0 8470

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, **SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 13.88 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from five wells

The use to which this water is to be applied is irrigation and supplemental irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 3 acre feet per acre for each acre irrigated during the irrigation season of each year; provided further that the right allowed herein shall be limited to any deficiency in the available supply of any prior right existing for the same land and shall not exceed the limitation allowed herein,

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer. The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is April 10, 1981

Actual construction work shall begin on or before September 10, 1982 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1982

Complete application of the water to the proposed use shall be made on or before October 1, 1983

WITNESS my hand this 10th day of September, 19 81


Water Resources Director

Handwritten initials