

## JACKSON COUNTY

## PERMIT TO APPROPRIATE THE PUBLIC WATERS

This is to certify that I have examined APPLICATION R-62820 and do hereby grant the same SUBJECT TO EXISTING RIGHTS AND THE FOLLOWING LIMITATIONS AND CONDITIONS:

This permit is issued to Culbertson Orchards by Duane Culbertson of 327 South Fir Street, Medford, Oregon 97501, phone 772-4298, for the construction of the Meyer Eastside and Meyer Westside Reservoirs and storage of water from seepage and natural runoff via Talent Lateral between Hansen Creek and the lower diversion point to be appropriated under Application 62821, Permit 46597, for frost control.

The dams will be LOCATED in the: SW 1/4 NW 1/4 of Section 1, Township 38 South, Range 2 West, WM, in the County of Jackson.

The maximum height will be a maximum of 5.0 feet above the stream bed or ground surface at the centerline. The top width will be 16.0 feet, slope of upstream face 2:1, slope of downstream face 2:1, and height of dam above water line when full 2.5 feet.

The area submerged by the reservoir, when full, will be Eastside Pond - 0.73 acre; Westside Pond - 0.9 acre, and the maximum depth of water will be 12.0 feet.

The location and dimension of the outlet or bypass, and control works are: Overflow consisting of a 12-inch diameter pipe to the Medford Irrigation District Canal. Inflow is controlled by use of two 8-inch diameter lines from the Talent Irrigation District Canal.

The structures are out of the channel.

The dams will be dug below the ground, with embankment around part.

The right hereunder shall be limited to the storage of 13.0 acre-feet, being 5.8 acre-feet in Eastside Reservoir and 7.2 acre-feet in Westside Reservoir.

The PRIORITY DATE of this permit is September 22, 1981.

Actual construction work shall begin on or before June 9, 1983 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1984.

WITNESS my hand this 9th day of June, 1982.

/s/ JAMES E. SEXSON

WATER RESOURCES DIRECTOR

PERMIT R 8390 W 04F 1981 A 10