

CERTIFICATE NO. 15101

* APPLICATION FOR A PERMIT

To appropriate the Public Waters of the State of Oregon

I, V. H. Thompson (Name of applicant)
of Dayton (Post office), County of Yamhill,
State of Oregon, do hereby make application for a permit to appropriate the
following described public waters of the State of Oregon, SUBJECT TO EXISTING RIGHTS:

If the applicant is a corporation, give date and place of incorporation No

1. The source of the proposed appropriation is Unnamed Stream (Name of stream)
a tributary of Palmer Creek

2. The amount of water which the applicant intends to apply to beneficial use is 0.38
cubic feet per second. One Source Only
(If water is to be used from more than one source, give quantity from each)

**3. The use to which the water is to be applied is Irrigation
(Irrigation, power, mining, manufacturing, domestic supplies, etc.)

4. The point of diversion is located 1200 ft. North and 200ft. East from the SW
(N. or S.) (E. or W.)
corner of Section 21, T. 4 S., R. 3 W. (Section or subdivision)
(If preferable, give distance and bearing to section corner)

(If there is more than one point of diversion, each must be described. Use separate sheet if necessary)
being within the SW $\frac{1}{4}$ SW $\frac{1}{4}$ of Sec. 21, Tp. 4 S.,
(Give smallest legal subdivision) (N. or S.)
R. 3 W., W. M., in the county of Yamhill
(E. or W.)

5. The Pipe to be 900'
(Main ditch, canal or pipe line) (Feet or feet)
in length, terminating in the NE $\frac{1}{4}$ SE $\frac{1}{4}$ of Sec. 20, Tp. 4 S.,
(Smallest legal subdivision) (N. or S.)
R. 3 W., W. M., the proposed location being shown throughout on the accompanying map.
(E. or W.)

DESCRIPTION OF WORKS

DIVERSION WORKS—

6. (a) Height of dam 9 feet, length on top 70 feet, length at bottom
30 feet; material to be used and character of construction Log and Planks
(Loose rock, concrete, masonry)
Spill over Dam
rock and brush, timber crib, etc., wasteway over or around dam)

(b) Description of headgate Timber - 1 opening 1' x 1'
(Timber, concrete, etc., number and size of openings)

(c) If water is to be pumped give general description 1 $\frac{1}{2}$ " Centrifugal
(Size and type of pump)
5 H.P. Electric - Head including friction, lift and pressure -
(Size and type of engine or motor to be used, total head water is to be lifted, etc.)
125 ft.

*A different form of application is provided where storage works are contemplated.

**Applications for permits to appropriate water for the generation of electricity, with the exception of municipalities, must be made to the Hydroelectric Commission. Either of the above forms may be secured, without cost, together with instructions by addressing the State Engineer, Salem, Oregon.

Application No. 18636

Permit No. 14271

PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF OREGON

Division No. District No.

This instrument was first received in the office of the State Engineer at Salem, Oregon on the 30th day of March, 1940, at 8:00 o'clock A.M.

Returned to applicant:

Corrected application received:

Approved:

July 30, 1940

Recorded in book No. 35 of

Permits on page 14271

CHAS. E. STRICKLIN

STATE ENGINEER

Drainage Basin No. 2 Page 90E

Fees Paid \$9.50

STATE OF OREGON

County of Marion,

} ss.

PERMIT

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.38 cubic feet per second measured at the point of diversion from the stream, or its equivalent in case of rotation with other water users, from

Unnamed Stream

The use to which this water is to be applied is Irrigation

If for irrigation, this appropriation shall be limited to 1/80th of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed 2 1/2 acre feet per acre for each acre irrigated during the irrigation season of each year.

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The priority date of this permit is March 30, 1940

Actual construction work shall begin on or before July 30, 1941 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1942

Complete application of the water to the proposed use shall be made on or before October 1, 1943

WITNESS my hand this 30th day of July, 1940

CHAS. E. STRICKLIN

STATE ENGINEER