

"CERTIFICATE NO. 67512"

ASSIGNED. See Misc. Rec., Vol. 7 Page 2260

Application No. 566608

Permit No. 42729

STATE OF OREGON WATER RESOURCES DEPARTMENT RECEIVED

Application for Permit to Appropriate Surface Water

DECEMBER 28 1977

WATER RESOURCES DEPT
SALEM, OREGON.

I, DG Shelter Products, Klamath Division
(Name of Applicant)

of P.O. Box 127, Klamath Falls
(Mailing Address) (City)

State of Oregon, 97601 Phone No. 884-7788
(Zip Code) do hereby

make application for a permit to appropriate the following described waters of the State of Oregon:

1. The source of the proposed appropriation is....Klamath River.....

....., a tributary of.....

2. The point of diversion is to be located100.481 ft. South..... and75.482 ft. West.....
(N. or S.) (E. or W.)

from the North 4 corner of Section 17, T39S, R9E, W.M.
(Public Land Survey Corner)

(If there is more than one point of diversion, each must be described)

..... being within the N E $\frac{1}{4}$ of the N W $\frac{1}{4}$ of
Sec. -8 17 Tp. 39 S R. 9 E., W.M., in the county of Klamath
(N. or S.) (E. or W.)

3. Location of area to be irrigated, or place of use if other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
39S	9E	8	Lot 4 (SE SW) Green Acres	16 Acres (Dust abatement)
39S	9E	8	Lot 14 (SESW)	6 Acres (Dust Abatement)
39S	9E	17	Lot 1 (NE NW)	Fire Protection
39S	9E	17	Lot 11 (NE NW)	Steam for manufacture, drying of lumber, water for fire suppression and cleaning of saws.

4. The amount of water which the applicant intends to apply to beneficial use is
cubic feet per second..... 80 Gal. per min.....
(If water is to be used from more than one source, give quantity from each)

5. The use to which the water is to be applied is ..used in boilers to produce steam for.....
manufacture of lumber and drying of lumber - Dust and fire protection - Cleaning
water for sawmill saws.

6.

DESCRIPTION OF WORKS

Include dimensions and type of construction of diversion dam and headgate, length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

1. 1-15 HP Jockey Pump 3" inlet 2" outlet-Hold fire system to pressure.
2. Tank Pump 15 HP 3" Inlet 2" Outlet-Keeps 100,000 gal. water tank full.
3. Emergency 125 HP-Elect. Fire Pump-Automatic to tank & fire system.
4. 2" line from tank to ER-to service boilers.
5. 1" line to SM from boiler room for saw & compressor water.

The fire system consists of an 8" CI Main which loops the plant - there are post indicator valves from this line to each system - each system has a dry vale. The water is contained at the dry valve with air pressure. The sprinkler system has 160 heads which are installed according to National Fire Protection Association Specs. If a fire occurs, the heads will melt at 160° releasing air and the system goes wet and floods the area where fire occurs. The water main is kept pressurized at 125 PSI by a 15 HP jockey pump and in case of fire or loss of pressure-a 150 HP pump automatically starts to hold pressure at 125 PSI.

Dust Abatement - Usage of standard water truck. Water pumped out of river and spread over log deck area when needed.

If for domestic use state number of families to be supplied

7. Construction work will begin on or before..... N/A.....
8. Construction work will be completed on or before..... N/A.....
9. The water will be completely applied to the proposed use on or before..... water presently taken from river.

Application No. 566608

Permit No. 42729

Remarks:.....

William Carey

Signature of Applicant

President


This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....completion.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before January 9,....., 19....78.....
March 6 78

WITNESS my hand this ..Eighth..... day of ..November....., 19....77.....
Sixth January 78

.....James E. SexsonWater Resources Director

By *West. Farmer*



This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the
28TH day of SEPTEMBER, 1977, at 8:00 o'clock
H.M.

Application No. *516668*

Permit No. *42729*

Application No..... 56668

Permit No..... 42729

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.18 cubic feet per second measured at the point of diversion from the stream, or its equivalent in case of rotation with other water users, from Klamath River

The use to which this water is to be applied is industrial use in a saw mill including fire protection and dust abatement

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated


and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The priority date of this permit is September 29, 1977

Actual construction work shall begin on or before March 10, 1979 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1980

WITNESS my hand this 10th day of March , 1978


James E. Axson
Water Resources Director