

Application No. 58898

Permit No. 44391

RECEIVED

RECEIVED

JUL 11 1979

JUN 20 1979

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for Permit to Appropriate Surface Water

WATER RESOURCES DEPT

WATER RESOURCES DEPT

SALEM, OREGON

SALEM, OREGON

I, Oregon Aqua-Foods, Inc.

(Name of Applicant)

of 88700 Marcola Road

Springfield

(Mailing Address)

(City)

State of Oregon

Phone No. (503) 746-4484

(Zip Code)

do hereby

make application for a permit to appropriate the following described waters of the State of Oregon:

1. The source of the proposed appropriation is McKenzie River

a tributary of Willamette River

2. The point of diversion is to be located 516.86 ft. South and 2228.7 ft. West

(N. or S.)

(E. or W.)

from the SE corner of the William M. Griffith D.L.C. No. 77 being within the SW 1/4 SW 1/4 of Section 20, T. 17 S., R. 2 W., W.M.

(Public Land Survey Corner)

See attached description and vicinity map showing existing hatchery intake

(If there is more than one point of diversion, each must be described)

structure.

being within the 1/4 of the 1/4 of

Sec. 20 Tp. 17S R. 2W, W.M., in the county of Lane

(N. or S.)

(E. or W.)

3. Location of area to be irrigated, or place of use if other than irrigation.

Township	Range	Section	List 1/4 1/4 of Section	List use and/or number of acres to be irrigated
17 S.	2 W	20	within NE 1/4 SW 1/4 & NW 1/4 SW 1/4	Domestic use only

4. The amount of water which the applicant intends to apply to beneficial use is 0.7 gpm  
cubic feet per second or ~ 300 gallons per day  
(If water is to be used from more than one source, give quantity from each)

5. The use to which the water is to be applied is Domestic Use

6. DESCRIPTION OF WORKS

Include dimensions and type of construction of diversion dam and headgate, length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Our intake consists of a 28' x 24' x 30' high concrete structure containing 2 10' wide rotating Royce screens w/ 0.14" mesh. Vertical bar screens w/ bars 5" o.c. protect the rotating screens. Water depth is about 12'. Two vertical turbine 200 H.P. constant speed allis chalmers type pumps & one vertical turbine 250 H.P. variable speed (allis chalmers) pump w/ U.S. Motors, deliver up to 41 M.G.D. into a 36" line ~ 650' to the hatchery. Most all of this water, except ~ 300 gpd, is for hatchery use.

If for domestic use state number of families to be supplied ~ 25 people (weekdays)

7. Construction work will begin on or before - construction completed

8. Construction work will be completed on or before January 1978

9. The water will be completely applied to the proposed use on or before same as above

Application No. 58898

Permit No. 44391

Remarks:.....

.....  
.....  
.....  
.....  
.....  
.....  
.....

*Steven Douglas Blair*  
Signature of Applicant  
*Water Quality Specialist*

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before ....., 19.....

WITNESS my hand this ..... day of....., 19.....

..... Water Resources Director

By .....

RECEIVED  
JUL 11 1979  
WATER RESOURCES DEPT  
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

*11<sup>th</sup>* day of *July*, 19 *79*, at *11:00* o'clock

*A.* M.

Application No. *58898*

Permit No. *44391*

Application No. 58898

Permit No. 44391

### Permit to appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.01 cubic feet per second measured at the point of diversion from the stream, or its equivalent in case of rotation with other water users, from McKenzie River

The use to which this water is to be applied is domestic supply for 25 people at Fish Hatchery

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The priority date of this permit is July 11, 1979

Actual construction work shall begin on or before September 27, 1980 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1981

Complete application of the water to the proposed use shall be made on or before October 1, 1982

WITNESS my hand this 27th day of September, 1979

*James E. Pearson*  
Water Resources Director